

INFORMATIONAL PROPOSAL

(For information only, not to be used for bidding)

NEBRASKA DEPARTMENT OF TRANSPORTATION

LETTING DATE: January 18, 2018

CALL ORDER: 500
CONTROL NO. SEQ. NO.: 51594 000

CONTRACT ID: 5594
PROJECT NO.: S-385-3(1024)

TENTATIVE START DATE: 10/01/2018

CONTRACT TIME: 15 Working Days

LOCATION: 'S' STREET TURN LANES NEAR BRIDGEPORT

IN COUNTY: MORRILL

BIDDER

GROUP 9 BITUMINOUS

NOTES

THE TOTAL AMOUNT OR WORK WHICH WILL BE ACCEPTED IN
THIS LETTING IS LIMITED TO \$ _____

THE NUMBER OF GROUP _____ CONTRACTS WHICH WILL BE
ACCEPTED IN THIS LETTING IS LIMITED TO _____.



NOTICE TO ALL BIDDERS

To report bid rigging activities, call: 1-800-424-9071

The U.S. Department of Transportation (DOT) operates the above toll-free “hotline” Monday through Friday, 8:00 a.m. to 5:00 p.m. eastern time. Anyone with knowledge of possible bid rigging, bidder collusion, or other fraudulent activities should use the “hotline” to report such activities.

The “hotline” is part of the DOT’s continuing effort to identify and investigate highway construction contract fraud and abuse and is operated under the direction of the DOT Inspector General. All information will be treated confidentially and caller anonymity will be respected.

LETTING QUESTIONS

Prior to the letting, any questions pertaining to the Special Provisions or the Plans for this project should be submitted to NDOT in a written format through the Bid Express (BidX) website at <https://www.bidx.com/ne/lettings>. Likewise, NDOT will post answers exclusively to the BidX website. All official answers will be identified as “Authorized by NDOT.” **Questions will not be answered verbally.**

STATE OF NEBRASKA
DEPARTMENT OF TRANSPORTATION

Required Provisions Supplemental to the
Standard Specifications for Highway Construction

I. Application

These contract provisions shall apply to all work performed on the contract by the contractor with his own organization and with the assistance of workmen under his immediate superintendence and to all work performed on the contract by piecework, station work, or by subcontract.

The contractor shall insert in each of his subcontracts all of the stipulations contained in the Special Provisions and these Required Provisions.

A breach of any of the stipulations contained in these Required Provisions may be grounds for termination of the contract.

II. Equal Opportunity

1. **Selection of Labor**

During the performance of this contract, the contractor shall not discriminate against labor from any other state.

2. **Nebraska Fair Employment Practices Act**

The contractor shall not discriminate against any employee or applicant for employment, to be employed in the performance of this contract with respect to his hire, tenure, terms, conditions, or privileges of employment, because of his race, color, religion, sex or national origin. The contractor agrees to post in a conspicuous place or places a notice to be provided by the State Highway Department which sets forth excerpts of the Act.

3. **Nebraska Equal Pay Act**

The contractor shall not discriminate on the basis of sex by paying wages to employees of one sex at a lesser rate than the rate paid to employees of the opposite sex for comparable work on jobs which have comparable requirements. An abstract of the Act is included on the notice which is provided by the State Highway Department.

November 7, 2017

III. Employment of Labor

1. General

No person under the age of sixteen (16) years, and no one whose age or physical condition is such as to make his employment dangerous to his health or safety, or to the health and safety of others shall be employed on any project. This paragraph shall not be construed to deny the employment of older people or physically handicapped persons, otherwise employable, where such persons may be safely assigned to work which they can ably perform.

No person currently serving sentence to a penal or correction institution shall be employed on any project.

Except as specifically provided under this section, workers who are qualified by training or experience to be assigned to projects of this character shall not be discriminated against on any grounds whatsoever.

2. Payrolls

Payrolls and basic records relating thereto will be maintained during the course of the work and preserved for a period of three years thereafter for all laborers and mechanics working on the site of the work.

The contractor's and subcontractor's payroll records shall be available for inspection by authorized representatives of the State Highway Department and authorized representatives of Federal Agencies.

The wages of labor shall be paid in legal tender of the United States, except that this condition will be considered satisfied if payment is made by a negotiable check, on a solvent bank, which may be cashed readily by the employee in the local community for the full amount, without discount or collection charges of any kind. Where checks are used for payment the contractor shall make all necessary arrangements for them to be cashed and shall give information regarding such arrangements.

No fee of any kind shall be asked or accepted by the contractor or any of his agents from any person as a condition of employment on the project.

No laborers shall be charged for any tools used in performing their respective duties except for reasonably avoidable loss or damage thereto.

Every employee on the work covered by this contract shall be permitted to lodge, board and trade where and with whom he elects and neither the contractor nor his agents, nor his employees shall directly or indirectly require as a condition of employment that an employee shall lodge, board or trade at a particular place or with a particular person.

No charge shall be made for any transportation furnished by the contractor or his agents to any person employed on the work.

November 7, 2017

No individual shall be employed as a laborer on this contract except on a wage basis, but this shall not be construed to prohibit the rental of teams, trucks or other equipment from individuals. No such rental agreement, or any charges for feed, gasoline, supplies, or repairs on account of such agreement, shall cause any deduction from the wages accruing to any employee except as authorized by the regulations hereinbefore cited.

IV. Safety and Accident Prevention

In the performance of this contract, the contractor shall comply with all applicable Federal, State and local laws governing safety, health and sanitation. The contractor shall provide all safeguards, safety devices and protective equipment and take any other needed actions, on his own responsibility or as the contracting officer may determine, reasonably necessary to protect the life and health of employees on the job and the safety of the public and to protect property in connection with the performance of the work covered by the contract.

V. Subletting or Assigning the Contract

The contractor shall perform with his own organization contract work amounting to not less than 30 percent of the total contract amount except that any items designated in the contract as "Specialty Items" may be performed by subcontract and the amount of any such "Specialty Items" so performed may be deducted from the total contract amount before computing the amount of work required to be performed by the contractor with his own organization.

Any items that have been selected as "Specialty Items" for the contract are listed as such in the Special Provisions found elsewhere in the contract.

No portion of the contract shall be sublet, assigned, or otherwise disposed of except with the written consent of the contracting officer or his authorized representative. Requests for permission to sublet assign or otherwise dispose of any portion of the contract shall be in writing and accompanied by a showing that the organization which will perform the work is particularly experienced and equipped for such work. The contractor shall give assurance that the minimum wage for labor as stated in his proposal shall apply to labor performed on all work sublet, assigned or otherwise disposed of in any way. Consent to sublet, assign or otherwise dispose of any portion of the contract shall not be construed to relieve the contractor of any responsibility for the fulfillment of the contract.

November 7, 2017

**SPECIAL PROVISIONS
FOR
STATE
PROJECT NO. S-385-3(1024)**

GENERAL CONDITIONS

Bids for the work contemplated in this proposal form will be received at the office of the Nebraska Department of Transportation in Room 104 of the Central Office Building at 1500 Highway 2 at Lincoln, Nebraska, on January 18, 2018, until 1:30 P.M.

- a. Bids submitted by mail should be addressed to the Nebraska Department of Transportation, c/o Contract Lettings Section, P.O. Box 94759, Lincoln, NE 68509-4759.
- b. Bids submitted electronically over the internet, shall be submitted using www.bidx.com.

The 2017 Edition of the Standard Specifications for Highway Construction, including all amendments and additions thereto effective at the date of the contract, are made a part of these Special Provisions, through reference.

The Required Provisions dated April 4, 1995, are attached to and are a part of this proposal form.

The attention of bidders is directed to the Required Provisions covering subletting or assigning the contract.

The proposal contains a statement that the contractor is complying with, and will continue to comply with, fair labor standards in the pursuit of his business and in the execution of the work contemplated in this proposal.

Fair labor standards shall be construed to mean such a scale of wages and conditions of employment as are paid and maintained by at least fifty percent of the contractors in the same business or field of endeavor as the contractor filing this proposal.

TRAINING SPECIAL PROVISIONS

This On-the-Job Training (OJT) Program was created by the Federal Highway Administration (FHWA) and the Nebraska Department of Transportation (NDOT) to fulfill the Training Special Provisions requirements of federal-aid construction contracts (23 CFR 230, Appendix B to Subpart A). The purpose of the provision is to address the under-representation of minority and female workers in the construction trades through the assignment of OJT training goals. Therefore, the training and upgrading of minorities and women toward journeyman status is a primary objective of this Training Special Provision.

Accordingly, the Contractor shall make every effort to enroll minority and women trainees (e.g., by conducting systematic and direct recruitment through public and private sources likely to yield minority and women trainees) to the extent that such persons are available within a reasonable area of recruitment.

All Contractors will be responsible for demonstrating the steps that they have taken to recruit minority and women trainees prior to a determination as to whether the Contractor is in compliance with this Training Special Provision. This training commitment is not intended, and

shall not be used, to discriminate against any applicant for training, whether a member of a minority group or not. The Contractor shall provide on-the-job training aimed at developing full journey-level status in the type of trade or job classification involved. The number of training hours under this Training Special Provision will be assigned to each Contractor as set forth below.

1. Under the NDOT Contractor-Specific On-the-Job Training (OJT) Program, OJT hours will be assigned to Contractors and will not be contract or project specific, except as noted in paragraph "a." below.
 - a. Contractors who **have not** received an OJT assignment and are awarded a federally funded project let by NDOT will be required to fulfill the number of OJT hours as identified in each contract. The number of training hours to be provided under this contract shall be: 0 hours.

A Contractor who has received an OJT assignment will be allowed to provide training on any NDOT-let project on which the Contractor is working as either a Prime Contractor or a subcontractor. A Contractor will have the flexibility to transfer trainees from one project to another after providing notification of the transfer to NDOT.
 - b. If this project does not have a contract-specific training requirement, or if the number of training hours is set at zero (0), NDOT will add a training pay item with a nominal 100-hour quantity, that may overrun or underrun, which will be utilized only if the Contractor elects to provide training on this contract.
2. In January each year, NDOT will allocate OJT assignments to Contractors based on the total average dollar amount of all work performed by a Contractor on NDOT-let projects during the previous three (3) calendar years. The total dollar amount will consist of:
 - a. The total dollar amount of the Contractor's prime contracts let by NDOT (both federal and state funded) minus the total dollar amount of the work subcontracted out to others, and
 - b. The total dollar amount of the subcontract work the Contractor performed for others on NDOT-let projects.

The Contractor’s average dollar amount for the previous three calendar years will be calculated, and training hours will then be assigned as follows:

<u>Three Year Average</u>	<u>Training Assignments</u>
Under \$2,500,000	0 hours
\$2,500,000 to 5,000,000	1,000 hours
Over \$5,000,000 to 7,500,000	1,500 hours
Over \$7,500,000 to 10,000,000	2,000 hours
Over \$10,000,000 to 15,000,000	3,000 hours
Over \$15,000,000 to 20,000,000	4,000 hours
Over \$20,000,000 to 25,000,000	5,000 hours
Over \$25,000,000 to 30,000,000	6,000 hours
Over \$30,000,000 to 40,000,000	8,000 hours
Over \$40,000,000 to 50,000,000	10,000 hours
Over \$50,000,000 to 60,000,000	12,000 hours
Over \$60,000,000	15,000 hours

Example: Contractor A, who averaged \$28.66 million, would be assigned 6,000 hours of OJT. Contractor B, who averaged \$10.33 million, would be assigned 3,000 hours of OJT. Contractor C, who averaged \$2.26 million, would not be assigned any OJT hours.

	2011	2012	2013	3 Year Average	2014 OJT Assignment
Contractor A	24.3	33.4	28.3	28.66	6,000 hours
Contractor B	9.3	11.9	9.8	10.33	3,000 hours
Contractor C	2.3	1.4	3.1	2.26	0 hours

3. The OJT hours assigned to a Contractor in January are to be completed during that calendar year (e.g., OJT hours assigned in January of 2014 are to be completed during the period of January 1, 2014 thru December 31, 2014).
 - a. If a Contractor exceeds the number of OJT hours assigned for a calendar year, the Contractor may request to bank up to 30 percent of the excess hours. Banked hours may then be credited toward the Contractor’s OJT assignment for the next calendar year.
4. A Contractor who has not received an annual OJT assignment and is required to provide OJT on a contract-specific basis cannot receive credit for any OJT hours provided by any other Contractor working on the project who has received a Contractor-specific OJT assignment.
5. Completion of the annual OJT assignment is the Contractor’s responsibility. The Contractor is not allowed to assign any of the OJT hours to any other Contractor. The Contractor must make a Good Faith Effort to enroll an adequate number of trainees and provide the trainees a sufficient number of hours training to achieve the Contractor’s annual OJT assignment.
6. While trainees may be assigned to NDOT-let federally or state funded projects, the Contractor should attempt to schedule and assign trainees so that at least 50 percent of a trainee’s hours are earned on federally funded projects - unless otherwise approved in advance by NDOT.

7. The Contractor must use an OJT program approved by NDOT and/or the FHWA. An OJT program shall be approved if it is reasonably calculated to meet the equal employment opportunity obligations of the Contractor and qualify the average trainee for journey-level status in the job classification concerned by the end of the training period. An approved OJT program must specify the number of hours required for a trainee to achieve journey-level status in each job classification. Furthermore, apprenticeship programs registered with the U.S. Department of Labor, Bureau of Apprenticeship and Training, or with a State apprenticeship agency recognized by the Bureau and training programs approved but not necessarily sponsored by the U.S. Department of Labor, Manpower Administration, Bureau of Apprenticeship and Training, shall also be considered acceptable provided they are being administered in a manner consistent with the equal employment obligations of federal-aid highway construction contracts.
8. The Contractor shall furnish each trainee a copy of the OJT Program he/she will follow in providing the training. The Contractor shall also provide each trainee with a certification showing the type and length of training satisfactorily completed.
9. The Contractor's Equal Employment Opportunity (EEO) Officer shall be responsible for administering the Contractor's OJT and monitoring the trainees' progress. The EEO Officer shall serve as the point of contact for NDOT regarding OJT information, documentation, and conflict resolution. If necessary, the EEO Officer may designate another individual to assist with the OJT monitoring responsibilities. NDOT must be provided the name and contact information for any such designee.
10. At least seven (7) days prior to commencing training, the Contractor must submit a "Request for Trainee Approval" form to NDOT for each individual to be enrolled as a trainee and a tentative list of the projects to which the trainee will be assigned. Requests for Trainee Approval may be submitted by mail, fax, or email.
11. If the Contractor submits a "Request for Trainee Approval" form to NDOT for an individual who is not a minority or female, or cannot replace departing trainees with minorities or females, the Contractor must also produce sufficient Good Faith Efforts documentation of the type set forth below. NDOT may reject non-minority male trainees for entry into the program if it determines that a Contractor failed to make sufficient Good Faith Efforts to hire minorities or female trainees and/or the Contractor failed to document or submit evidence of its Good Faith Efforts to do so.
12. Any training hours provided to a trainee prior to the Contractor receiving approval from NDOT will not be credited toward the Contractor's annual OJT assignment.
13. When an individual is first enrolled as a trainee, the individual will be approved for the number of hours of OJT required to achieve journey-level status in the classification for which the individual is to receive training. (A Contractor will not be penalized if a trainee does not achieve the full number of hours for which the trainee is approved.)
14. If the Contractor is unable to provide a trainee the full number of training hours required to achieve journey-level status on one project, the trainee should be transferred to other NDOT-let projects on which the Contractor is working.
15. At least one (1) day before all such transfers of trainees are made, the Contractor must provide NDOT in writing the name of the trainee and current project, the project to which

the trainee will be transferred, and when the transfer is to take place. Notifications of trainee transfers may be submitted by mail, fax, or email.

16. Any training hours provided to a transferred trainee prior to the Contractor having notified NDOT of the transfer will not be credited toward the Contractor's annual OJT assignment.
17. No individual may be employed as a trainee in any classification in which they have successfully completed training leading to journey-level status or in which they have been employed at journey-level. No individual may be employed as a trainee in any classification with a lower skill level than any classification in which they have successfully completed training leading to journey-level status or in which they have been employed at journey-level (e.g., an individual who has achieved journey-level status as an equipment operator may not be trained as a laborer). The Contractor should satisfy this requirement by including appropriate questions in the employee application or by other suitable means. Regardless of the method used, the Contractor's records should document the findings in each case.

An individual may be trained in multiple classifications that require relatively equal skill levels but different skill sets (e.g., an individual who has received training as a milling machine operator may also receive training as a roller operator, or a scraper operator, etc.). Preferably, an individual should have achieved journey-level status in a classification before beginning training in another classification.

The Contractor must request and receive approval from NDOT for an individual to receive training in a classification other than the classification for which the individual was originally approved. Any training hours provided prior to receiving approval from NDOT will not be credited toward the Contractor's annual OJT assignment.

18. Training shall be provided in construction crafts rather than clerk-typist or secretarial-type positions. Training is permissible in positions that are not assigned to a specific project such as office engineers, estimators, timekeepers, shop mechanics, etc., if the selected OJT program includes these classifications. Training in such positions will not be eligible for reimbursement, but will be eligible to be credited toward the Contractor's annual OJT assignment.
19. Some off-site training is permissible as long as the training is an integral part of an approved OJT program and does not comprise a significant part of the overall training (e.g., 16 hours training per trainee per year in areas such as jobsite safety or accident response would be permissible). A copy of a training certificate, agenda, or curriculum must be provided to verify off-site training.
20. The Contractor will be reimbursed \$2.00 per each hour of training provided in accordance with an approved OJT program and the NDOT Training Special Provisions.
21. Contractors shall be allowed to transfer trainees or utilize trainees on other NDOT-let projects which do not contain the Training Special Provisions. NDOT will utilize a Change Order / Supplemental Agreement to incorporate the Training Special Provisions and the appropriate pay item into the contracts of such projects.
22. On all federally funded NDOT-let projects, trainees must be paid at least 60 percent of the appropriate minimum journey-level rate specified in the contract for the first half of

the training period, 75 percent for the third quarter, and 90 percent for the last quarter of the training period - or the appropriate rates approved by the U.S. Department of Labor or the U.S. Department of Transportation in connection with the program in which the trainee is enrolled.

23. In order to document and evaluate a trainee's progress toward journey-level status, the Contractor must provide NDOT at the end of each month a "Special Training Provision Monthly On-The-Job Training Report" listing each trainee, the number of hours trained during the month, and the total number of hours trained as of the date of the report.

NOTE: The monthly reporting requirements may change if/when on-line reporting is implemented by NDOT.

24. If a trainee's employment is terminated for any reason prior to completion of the number of OJT hours for which the individual was approved, the Contractor must make Good Faith Efforts to replace the trainee with another minority or female.
25. Contractors must submit an annual summary report to NDOT by January 15th each year giving an account of all trainee hours provided during the previous year. The report shall show a breakdown of training provided on each project and/or contract.
26. Contractors will have fulfilled their OJT responsibilities if they have provided acceptable training for the number of hours assigned, or have demonstrated that they made a Good Faith Effort to provide the number of OJT hours assigned. Where a Contractor cannot meet his or her annual training hour goal with females and minorities, the Contractor remains responsible for demonstrating the Good Faith Efforts taken in pursuance of the goal. Examples of what actions constitute Good Faith Efforts are set forth below. NDOT will make compliance determinations regarding the Training Special Provisions based upon either attainment of the annual goal or Good Faith Efforts to meet it.
27. Good Faith Efforts are those designed to achieve equal opportunity through positive, aggressive, and continuous results-oriented measures (23 CFR § 230.409(g)(4)). Good Faith Efforts should be taken as trainee-hiring opportunities arise and when minorities and women are under-represented in the Contractor's workforce. NDOT will consider all Contractors' documentation of Good Faith Efforts on a case-by-case basis and take into account the following:
- a. Availability of minorities, females, and disadvantaged persons for training;
 - b. The potential for effective training;
 - c. Duration of the contract;
 - d. Dollar value of the contract;
 - e. Total normal work force that the average Contractor could be expected to use;
 - f. Geographic location;
 - g. Type of work;
 - h. The need for journey level individuals in the area.

Good Faith Efforts may include, but are not limited to, documentation of efforts to:

- Contact minority and female employees to gain referrals on other minority and female applicants;
- Refer specific minorities and females to training programs and specifically request these trainees by name in the future;
- Upgrade minority and female unskilled workers into the skilled classifications when possible;
- Accept applications at the project site or at the Contractor's home office;
- Review and follow up on previously received applications from minorities and females when hiring opportunities arise;
- Maintain monthly evaluations that monitor efforts made to achieve diversity in the Contractor's workforce in general (i.e., significant numbers of minorities and females employed on a company-wide basis);
- Provide incentives for project management personnel or superintendents when hiring goals are met on a project (i.e., similar to performance bonuses paid when a job is completed in a timely manner and under budget).

28. Liquidated damages will be assessed the Contractor for failure to demonstrate a Good Faith Effort to achieve their full OJT assignment or for failure to demonstrate a Good Faith Effort to achieve their full OJT assignment with minority and women trainees.

Liquidated damages will be assessed at the rate of \$4.00 per hour for the number of OJT hours not achieved or, even if achieved, the number of OJT hours in which the Contractor fails to demonstrate Good Faith Efforts to hire minorities and women. (e.g., if the Contractor was assigned 3,000 hours but only achieved 2,000 hours and did not demonstrate a Good Faith Effort, the liquidated damages would be assessed at 1,000 hours x \$4.00 = \$4,000.00.)

29. NDOT will invoice a Contractor for liquidated damages assessed as a result of the Contractor's failure to demonstrate a Good Faith Effort to achieve the number of OJT hours assigned.

The Contractor's failure to promptly pay any invoice for liquidated damages may result in the Contractor being disqualified to bid work with NDOT for a time period determined by the Director/State Engineer.

30. At the end of the calendar year, if the dollar amount of work the Contractor performed on NDOT-let projects is substantially below the three-year average upon which the Contractor's OJT assignment was based, the Contractor's OJT goal for that year may be adjusted according to the table in Paragraph 2. above.

31. The established per hour unit price for the item "Training" shall be full compensation for all costs incurred, which includes but is not limited to providing the necessary

supervision, labor, equipment, tools and material. Any additional costs due to payment of wages in excess of the minimum rates specified and for the payment of any fringe benefits shall not be paid for directly, but shall be considered subsidiary to the items for which direct payment is made.

AMENDMENT TO CONSTRUCTION TRAINING REPORT REQUIREMENTS

The last sentence under Paragraph C., on Page 5 of the Standard Federal Equal Employment Opportunity Construction Contract Specifications, dated November 3, 1980, is void.

FHWA Form 1409 "Federal-aid Highway Construction Contractor's Semi-Annual Training Report" is not required.

STATUS OF UTILITIES

The following information is current as of December 12, 2017.

Aerial and/or underground utilities may exist within the limits of this project. The Contractor shall determine to their satisfaction the extent of occupancy of any utility facilities located within the project construction areas and the extent of conflict with the proposed work under this contract.

At this time, no utilities have been required to relocate their facilities.

Any utility adjustments or interruption of service for the convenience of the Contractor shall be the sole responsibility of the Contractor.

To arrange for utilities to locate and flag their underground facilities, contact Diggers Hotline of Nebraska at 1-800-331-5666, or dial 811.

Any work necessary will be concurrent with construction.

STATUS OF RIGHT OF WAY

The right of way for this project has been acquired and physical possession is held by the State of Nebraska and ready for the Contractor's use, except tracts listed below:

Unacquired Right-of-Way Tracts as follows:

Tract Number	Status of Tract	Hearing Date
None	None	None

Right-of-Way Tracts with Pay Items:

Tract Number	Pay Items
None	None

- No encroachments on the old right of way.
- Acquisition of right of way is not required for this project.

**SPECIAL PROSECUTION AND PROGRESS
(Polyester Geogrid-Fabric Composite Placement Location)**

The Polyester Geogrid-Fabric Composite shall be installed across the full width of the pavement, throughout the length of the project, including the two-way left turn lane on the project.

**SPECIAL PROSECUTION AND PROGRESS
(Milling/Asphaltic Concrete Placement)**

Traffic will not be allowed on any milled asphaltic concrete surface.

NOTICE TO BIDDERS

The following table illustrates NDOT's computation of concrete pavement repair quantities based on preliminary inspection and is intended to aid the Contractor in bidding this project:

Concrete Pavement Repair Item	Approx. # of Repairs	Approx. Sq Yds of Repairs
Type 'A', Full Depth	24	53.3
Type 'B', Full Depth	10	55.6
Type 'C', Full Depth	6	93.4

STATUS OF ENVIRONMENTAL COMMITMENTS

Project No. S-385-3(1024)
Control No. 51594
Location: 'S' Street Turn Lanes Near Bridgeport

404 Permit Required Yes
 No

Comments: No 404 permit required.

Individual 401 Water Quality Certification Required Yes
 No

State Title 117 Waters (COE Non-Jurisdictional) Yes
 No

Floodplain Permit Required Yes
 No

Comments: No floodplain permit required.

Historic Clearance Yes Tier II Approved 8/8/2017
 No

Comments: No historic properties affected.

Threatened & Endangered Species Clearance Required Yes FHWA – NA
 No Approved: NGPC – 9/26/2017
USFWS – NA

Comments: No Effect

FHWA Environmental Clearance Yes
 N/A

Comments: State Funds Only

NPDES/Stormwater Permit No.: NA

Special Provisions: See attached Environmental Commitment sheet

Special Notes on Plans:

I have compared environmental documentation and project correspondence with environmental commitments shown on this form and found them to be accurate and complete.

Dillon Dittmer DD 10/26/17 Melissa Marinovich mm 10/24/17 Jon Barber JB 10/19/17 EDU PM CW 10/25/17 Jason Jung JJ 10/25/17 Ron Poe RP 10/20/17 EPU PM KB 10/24/17
(Initial) (Date) (Initial) (Date) (Initial) (Date) (Initial) (Date) (Initial) (Date) (Initial) (Date) (Initial) (Date)

ENVIRONMENTAL COMMITMENT

Control No.: 51594 **Project No.:** S-385-3(1024)

Project Name: 'S' Street Turn Lanes Near Bridgeport

Below are the Conservation Conditions that will be required for this project. All conditions and regulations of any permit obtained for this project will be followed by the contractor.

(Responsible Party for the measure is found in parentheses)

Conservation Measure for Environmentally Sensitive Areas

The Contractor shall not stage, store, waste or stockpile materials and equipment in undisturbed locations, or in known/potential wetlands and/or known/potential streams that exhibit a clear "bed and bank" channel. Potential wetland areas consist of any area that is known to pond water, swampy areas or areas supporting known wetland vegetation or areas where there is a distinct difference in vegetation (at lower elevations) from the surrounding upland areas. (Contractor, NDOT District)

- Regulated Wetlands and/or Water Resources for this project have been identified and delineated in the field by NDOT. The above condition pertains to the areas within delineated wetland boundaries (Wetlands – Do Not Disturb) and/or environmentally sensitive areas (Area of Environmental Concern – Do Not Disturb) as shown in the 2-W aerial plan sheets and/or the erosion control plan sheets included in the plan set. If access to any of these areas is required to complete the project construction, the NDOT construction project manager shall coordinate with the Environmental Permits Unit to determine need for field verification and/or permitting requirements prior to disturbance of the area. (Contractor, District Construction)

Contact Person: Kimberly Baker, Highway Environmental Biologist, (402) 479-4544

General Conservation Conditions

Changes in Project Scope. If there is a change in the project scope, the project limits, or environmental commitments, the NDOT Environmental Section must be contacted to evaluate potential impacts prior to implementation. Environmental commitments are not subject to change without prior written approval from the NDOT Environmental Section. (District Construction, Contractor)

Threatened and Endangered Species. The Contractor shall reference the Nebraska Game and Parks Commission website for a reference of federal and state listed species that may occur in the project vicinity prior to starting project construction. These guidance document can be found at:

- <http://agcne.org/member-portal/>
- <http://outdoornebraska.gov/naturalheritageprogram/>

If federal or state listed species are observed during construction, stop work and contact the NDOT Environmental Section to determine action required prior to resuming work. (NDOT Environmental, District Construction, Contractor)

Refueling. Refueling will be conducted within the confines of the paved roadway surface or within the boundaries of an approved stockpile/staging site. (Contractor)

Restricted Activities. Any project related activities that occur outside of the project limits (includes the paved surface and within 12 inches of the paved surface) must be environmentally

cleared/permited with the Nebraska Game and Parks Commission as well as any other appropriate agencies by the contractor and those clearances/permits shall be submitted to the District Construction Project Manager prior to the start of the above listed project activities. The contractor shall submit a NDOT Plant Site/Stockpile Site Request Identification and Evaluation Form (DR Form 56) and/or a Borrow Site/Waste Site Request Identification and Evaluation Form (DR Form 119) as appropriate, and include information such as an aerial photo showing the proposed activity site, a plan-sheet or drawing showing the location and dimensions of the activity site, ground photos showing the existing conditions at the proposed activity site, etc. The contractor must receive notice of acceptance from NDOT, prior to starting the above listed project activities. These project activities cannot adversely affect state and/or federally listed species or designated critical habitat. Fill cannot be placed in Wetland, Stream or other Waters of the U.S without authorization. (NDOT Environmental, District Construction, Contractor)

Waste/Debris. Construction waste/debris will be disposed of in areas or a manner which will not adversely affect state and/or federally listed species and/or designated critical habitat. (Contractor)

Contact Person: Melissa Marinovich, Highway Environmental Biologist, (402) 479-3546

Encountering Unexpected Waste

If contaminated soils and/or water or hazardous materials are encountered, then all work within the immediate area of the discovered hazardous material shall stop until NDOT/FHWA is notified and a plan to dispose of the Hazardous Materials has been developed. Then NDEQ shall be consulted and a remediation plan shall be developed for this project. The potential exists to have contaminants present resulting from minor spillage during fueling and service associated with construction equipment. Should contamination be found on the project during construction, the NDEQ shall be contacted for consultation and appropriate actions to be taken. The Contractor is required by NDOT's Standard Specification section 107 (legal relations and responsibilities to the public) to handle and dispose of contaminated material in accordance with applicable laws. (NDOT District, Contractor)

Contact Person: Carrie Wencel, Highway Environmental Biologist, (402) 479-4836

Construction Stormwater

This project does not require a Construction Stormwater Permit or a Storm Water Pollution Prevention Plan (SWPPP). Temporary water pollution prevention practices (including sediment and erosion control measures) are still required by Nebraska State Title 119. The Contractor shall exercise every reasonable precaution throughout the life of the contract to prevent sedimentation within rivers, streams, impoundments (lakes, reservoirs, etc.), the project site, and adjacent property. (Contractor)

Contact Person: Ron Poe, Highway Environmental Program Manager, (402) 479-4499

STORM WATER DISCHARGES (1-43-1217)

In compliance with the Federal Water Pollution Control Act, authorization to discharge storm water on this project has been granted under National Pollutant Discharge Elimination System (NPDES) General NPDES Permit Number NER110000 for Storm Water Discharges from Construction Sites to Waters of the State of Nebraska. This permit became effective on January 1, 2008.

Contractors are advised that, under the Construction Storm Water General Permit, ***plant sites, camp sites, storage sites, and borrow or waste sites not shown on the plans may be***

subject to separate NPDES permit authorization requirements for stormwater discharges from those locations. Contractors shall be responsible for verifying the need for NPDES permit coverage with the Nebraska Department of Environmental Quality (NDEQ). When required for these locations, the filing of a "Notice of Intent" shall be made by the Contractor directly to the NDEQ.

Additionally, asphalt (SIC Code 2951) or concrete (SIC Code 3273) batch plants that are owned by a private contractor and are operated on a contract-for-service basis to perform work for the Contractor completing the project may be subject to NPDES General Permit Number NER000000 for Industrial Storm Water Discharges. While the plant may be required for completion of the project, it is not under the control of the Department (or other project owner); and the filing of a "Notice of Intent" shall be made by the Contractor directly to the NDEQ.

The NDEQ may be contacted at 402-471-4220 for additional information.

REQUIRED SUBCONTRACTOR/SUPPLIER QUOTATIONS LIST (1-43-1217)

All bidders must provide to the NDOT the identity of all firms who provided quotations on all projects, including both DBEs and non-DBEs. This information must be on a form provided by the NDOT Contracts Office.

If no quotations were received, the bidder must indicate this in the space provided.

Each bidder will be required to submit one list per letting to cover all projects bid.

WORKER VISIBILITY (1-43-1217)

Pursuant to Part 634, Title 23, Code of Federal Regulations, the following modified rule is being implemented:

Effective on January 1, 2008, all workers within the right-of-way who are exposed either to traffic (vehicles using the highway for purposes of travel) or to construction equipment within the work area shall wear high-visibility safety apparel.

High-visibility safety apparel is defined to mean personal protective safety clothing that:

- 1 - is intended to provide conspicuity during both daytime and nighttime usage, and
- 2 - meets the Performance Class 2 or Class 3 requirements of the ANSI/ISEA 107-2004 publication titled "American National Standards for High-Visibility Safety Apparel and Headwear."

**SPECIAL PROSECUTION AND PROGRESS
(Federal Immigration Verification System)
(1-43-1217)**

The Contractor shall register with and use a Federal Immigration Verification System to determine the work eligibility status of newly hired employees physically performing services within the State of Nebraska. The Prime Contractor shall contractually require every subcontractor to register with and use a Federal Immigration Verification System to determine the work eligibility status of newly hired employees physically performing services within the State of Nebraska.

The Federal Immigration Verification System shall be an electronic verification of the work authorization program of the Illegal Immigration Reform and Immigration Responsibility Act of 1996, 8 U.S.C. 1324a, known as the E-Verify Program. The Contractor may use an equivalent Federal program designated by the United States Department of Homeland Security or other Federal agency authorized to verify the work eligibility status of a newly hired employee. The equivalent program shall comply with the Immigration Reform and Control Act of 1986.

The Prime Contractor shall furnish a letter to the NDOT Construction Division in Lincoln on company letterhead and signed by an officer of the company stating that documentation is on file certifying that the Contractor and all subcontractors have registered with and used a Federal Immigration Verification System. The Contractor shall maintain all records of registration and use for a period of three years and make records available upon request. The Contractor shall contractually require subcontractors to maintain all records for a period of three years and make records available upon request.

Payment will not be made to the Contractor for using the Federal Immigration Verification System or the maintenance of the records. This work shall be subsidiary to the work being performed.

The Contractor's Certification shall become part of the final records of the Contract. The Department considers this document to have direct bearing to the beginning interest date and may affect the amount of interest earned.

**PROPOSAL GUARANTY BID BOND (BID BOND)
(1-43-1217)**

Paragraph 1.b. of Subsection 102.14 in the Standard Specifications is void.

**LIABILITY INSURANCE
(1-49-0118)**

Paragraph 1.b.(5) of Subsection 107.15 in the Standard Specifications is void and superseded by the following:

- (5) Automobile liability coverage shall be obtained from an insurance carrier who is licensed in Nebraska and any other State in which the project is located.

Paragraph 1.c. of Subsection 107.15 is amended to include the following:

Limit: Statutory coverage for Nebraska and for any other State in which the project is located.

Paragraph 1.c.(3) of Subsection 107.15 is void and superseded by the following:

- (3) Workers' compensation coverage shall be obtained from an insurance carrier who is licensed in Nebraska and any other State in which the project is located.

Paragraph 1.f.(5) of Subsection 107.15 in the Standard Specifications is void and superseded by the following:

- (5) Prior to execution of the contract, Contractor shall provide the State of Nebraska, Department of Transportation evidence of such insurance coverage in effect in the form of an ACORD® (or equivalent) certificate of insurance executed by a licensed representative of the participating insurer(s). Certificates of insurance shall show the Nebraska Department of Transportation as the certificate holders.

Paragraph 1.f. of Subsection 107.15 is amended to include the following:

- (9) For so long as insurance coverage is required under this agreement, the Contractor shall have a duty to notify the State of Nebraska Department of Transportation (State) when the Contractor knows, or has reason to believe, that any insurance coverage required under this agreement will lapse, or may be cancelled or terminated. The Contractor must forward any pertinent notice of cancellation or termination to the State by mail (return receipt requested), hand-delivery, email, or facsimile transmission within 2 business days of receipt by Contractor of any such notice by an insurance carrier. Notice shall be sent to the State at the following address:

Nebraska Department of Transportation
Construction Division -- Insurance Section
1500 Highway 2, P.O. Box 94759
Lincoln, NE 68509-4759
Facsimile No. 402-479-4854
NDOT.ConstructionInsurance@nebraska.gov

CONSTRUCTION DETAILS

TEMPORARY WATER POLLUTION CONTROL (2-1-1217)

Section 204 in the Standard Specifications is void.

**CONSTRUCTION STORMWATER MANAGEMENT CONTROL
(2-1-1217)**

A. General

1. This Section defines some best management practices (BMPs) for erosion and sediment control measures and construction practices the Contractor shall use to prevent soil erosion and avoid water pollution.
2.
 - a. The Department and the Contractor are co-permittees of the NPDES Construction Storm Water General Permit.
 - b. The Contractor shall comply with all conditions required by the current NPDES Construction Storm Water General Permit.
3. The Contractor shall exercise every reasonable precaution throughout the life of the contract to prevent silting of the waters of the state, the project site, and adjacent property. Construction of drainage facilities, as well as performance of other contract work which will contribute to the control of siltation, shall be carried out in conjunction with earthwork operations or as soon thereafter as is practicable.
4.
 - a. The Contractor shall take sufficient precautions to prevent pollution of the waters of the state, the project site, and adjacent property from construction debris, petroleum products, chemicals, or other harmful materials.

The Contractor shall conduct and schedule the operations to avoid interference with any protected species.
 - b. The Contractor shall comply with all applicable statutes relating to pollution of the waters of the state and fish and game regulations.
5. All construction debris shall be disposed in a manner that it cannot enter any waterway. Excavation shall be deposited as to protect the waters of the state from siltation.
6. All erosion and sediment control measures shall be properly installed and maintained by the Contractor until all permanent drainage facilities have been constructed, and all slopes are sufficiently vegetated to be an effective erosion deterrent; or until tentative acceptance of the work.
7. All erosion and sedimentation resulting from the Contractor's operations and the weather conditions must be corrected by the Contractor.

**LIMITATION OF OPERATIONS
(2-1-1217)**

A. General

1. The maximum exposed surface area for the Contractor's operations in excavation, borrow, and embankment is 18 acres (72,800 m²) plus an equal area of clearing and grubbing/large tree removal. A written request for an increase in the maximum exposed surface area may be approved by the Engineer. This approval will be based on the soil, moisture, seasonal conditions, the Contractor's operation, or other conditions.
2. The Engineer shall have the authority to reduce the maximum exposed surface area when any of the following conditions warrant:
 - a. Soil and moisture conditions are such that erosion is probable.
 - b. Seasonal conditions may force extended delays.
 - c. Proximity to the waters of the state requires more stringent controls.
 - d. Equipment and personnel available on the job is not sufficient to properly maintain erosion and dust control measures.
 - e. Any other environmental condition in the area that may exist which would be affected by erosion from the project.
3. Construction operations in rivers, streams, wetlands, and impoundments shall be restricted to those areas specifically shown in the contract. Rivers, streams, wetlands, and impoundments shall be promptly cleared of all false work, piling, debris, or other obstructions placed therein or caused by the construction operations.
4. Fording and operation of construction equipment within streams and wetlands will not be allowed, unless explicitly allowed in the contract. Streams are defined as any area between the high banks, regardless of the flow conditions.

**CONSTRUCTION METHODS
(2-1-1217)**

A. General

1. The Contractor shall conduct all construction activities and install temporary erosion control measures, as necessary, to control sediment and avoid soil erosion during construction.
2. The Contractor shall incorporate all permanent erosion control features into the project at the earliest practicable time.
3. Construction stormwater management control measures for Contractor obtained work areas located outside the right-of-way, such as borrow site operations, haul

roads, plant sites, staging sites, waste sites, equipment storage sites, etc. are the sole responsibility of the Contractor. All construction stormwater management control measures for these areas are at the Contractor's expense. The Contractor is responsible for securing all required permits for use of these sites.

4. The construction stormwater management procedures contained herein shall be coordinated with any permanent erosion control measures specified elsewhere in the contract to the extent practical to assure economical, effective, and continuous erosion and sediment control throughout the construction period.
5. The Contractor shall be responsible to limit erosion and prevent siltation into the waters of the state during the construction period, as well as during the times that work may be suspended.
6.
 - a. All erosion and sediment control items shall be installed by personnel who are knowledgeable in the principles and practice of various BMP installations.
 - b. The installation of all erosion and sediment control items shall be done under the direct supervision of the Contractor's employee who has successfully completed training provided by the Department and has been certified as an Erosion and Sediment Control Inspector (Inspector). The Contractor's Inspector shall be present at each site during installation to direct and inspect all erosion and sediment control BMP installations.
 - i. The NDOT Erosion and Sediment Control Inspector Certification is obtained by completing an Erosion and Sediment Control Inspector Training Course provided by the Nebraska Department of Transportation and passing the examination that accompanies the training.
 - c. The Contractor shall notify the Engineer of all employees, who have been certified as Inspectors, who will be on the project to direct and inspect all erosion and sediment control BMP installations.
 - d. No payment will be made for any erosion and sediment control item unless a Contractor's Inspector was present to directly supervise and inspect the work.
 - e. No payment will be made for any erosion and sediment control item that is not properly installed. All erosion and sediment control items shall be installed as per the contract.

**ENVIRONMENTAL COMMITMENT DOCUMENT
(2-1-1217)**

A. Environmental Commitment Document

1. a. An Environmental Commitment Document will be created by the Department to identify all project specific environmental commitments and will be included in the Contract.
- b. The Department will provide information for the following, when applicable:
 - i. Storm Water Pollution Prevention Plan (SWPPP)
 - ii. U.S. Army Corps of Engineers (USACE) Section 404 Permit
 - iii. Nebraska Department of Environmental Quality 401 Water Quality Certification
 - iv. State Title 117 Waters (USACE Non-Jurisdictional)
 - v. Floodplain Permit
 - vi. Historic Clearance
 - vii. Endangered Species Act Clearance
 - viii. Nebraska Nongame and Endangered Species Conservation Act Clearance
 - ix. National Environmental Policy Act Compliance
 - x. NPDES Construction Stormwater Permit (within Right-of-Way limits, only)
 - xi. Conservation Measures
 - xii. Migratory Bird Treaty Act
 - xiii. Bald and Golden Eagle Protection Act Compliance
 - xiv. Other pertinent issues
- c. The Contractor shall provide information for the following, when applicable:
 - i. Temporary Erosion Control Plan
 - ii. Spill Prevention and Control Plan
 - iii. Migratory Bird Treaty Act Compliance Plan

- iv. Name and telephone number of the Contractor's representative responsible for the Environmental Commitments
- v. Name and telephone number of the employees that are NDOT-Certified Erosion and Sediment Control Inspectors
- vi. Critical Path Construction Schedule
- vii. Other items as defined elsewhere in the contract

**STORM WATER POLLUTION PREVENTION PLAN (SWPPP)
(2-1-1217)**

A. General

- 1. A SWPPP is required for projects that construction activities will cause a land disturbance of one (1) acre or more. The Department will prepare the SWPPP for the areas within the Right-of-Way, temporary easements and permanent easements.
- 2. For projects not requiring a SWPPP, the Contractor shall comply with the requirements of Environmental Commitment Document, Paragraph 1.b. of this Special Provision, as applicable.
- 3. Contractor obtained work areas, located on private property, are not included in the NDOT Project SWPPP.

B. Temporary Erosion Control Plan

- 1. The Contractor shall prepare and submit the Temporary Erosion Control Plan prior to the start of any work. The Contractor shall not begin work until the Temporary Erosion Control Plan has been submitted to the Engineer and appropriate erosion control measures are in place. Payment for any work on the contract will be withheld if erosion control measures are not in place or properly maintained.
- 2. The Temporary Erosion Control Plan will be reviewed at project progress meetings. All active Contractors shall have their Inspectors present and work in cooperation to determine any necessary changes. Necessary changes will be documented on the Temporary Erosion Control Plan by the Engineer.
- 3. Payment for preparing the Temporary Erosion Control Plan, inspections and meeting reviews are subsidiary to items that direct payment is made.

C. Spill Prevention and Control Plan

- 1. All project activities shall be addressed in the Spill Prevention and Control Plan. The Contractor shall prepare and submit the plan to the Engineer and install all appropriate spill prevention and control measures prior to the start of any work.

2. The Spill Prevention and Control Plan shall clearly state measures to prevent, contain, document and clean up a spill. It shall state measures for disposal of the contaminated material, disposal documentation and incident review to train personnel to prevent spills from reoccurring.
3. Spill Prevention and Control Plans are applicable to construction sites where hazardous materials are stored, used and/or generated onsite. Hazardous materials include, but not limited to: hazardous wastes, pesticides, paints, cleaners, petroleum products, fertilizers, solvents and porta-potty wastes.
4. Direct payment will not be made for the Spill Prevention and Control Plan.

D. Migratory Bird Treaty Act Compliance Plan

1. The Contractor shall not begin work until a Migratory Bird Treaty Act Compliance Plan has been submitted to the Engineer and appropriate nesting migratory bird avoidance measures are in place.
2. a. The Contractor shall clearly state the necessary measures they intend to use to avoid a "Take" of nesting migratory birds in the Migratory Bird Treaty Act Compliance Plan. Measures may include but are not limited to:
 - i. Clearing and grubbing prior to April 1st or after September 1st
 - ii. Tree removal prior to April 1st or after September 1st
 - iii. Clearing empty nests on structures prior to April 1st
 - iv. Maintaining clear structures until commencement and throughout the duration of work on structures
 - v. Netting structures to prevent nesting
 - vi. Commitment to perform surveys according to protocol
 - vii. Hire a biologist to survey areas to be disturbed prior to commencement of work during the nesting season
 - viii. Submittal of required bird survey reports
 - ix. Training of Contractor Personnel to insure compliance
3. a. The Migratory Bird Treaty Act Compliance Plan is applicable to the entire project site to avoid the "Take" of migratory birds protected under the Migratory Bird Treaty Act.
 - b. "Take" is defined as: pursuit, hunt, shoot, wound, kill, trap, capture, collect, or attempt to pursue, hunt, shoot, wound, kill, trap, capture, or collect.

4. The Migratory Bird Treaty Act Compliance Plan shall adhere to the NDOT's Avian Protection Plan located at:

<http://www.dot.nebraska.gov/media/3952/avian-protection-plan.pdf>

Direct payment will not be made for the Migratory Bird Treaty Act Compliance Plan.

E. SWPPP Inspection

1. The Contractor shall accompany the Engineer on inspections in accordance with the NPDES Construction Storm Water General Permit.
2. The SWPPP will be maintained and updated by the Engineer as work progresses and site conditions change to accurately describe the BMPs that are currently in place.
3. The Contractor's participation in SWPPP inspections, maintenance and updates shall begin on the first day construction activities cause land disturbance and end on the date of project completion as evidenced as the completion date in the District Engineer's Letter of Tentative Acceptance.
4.
 - a. The Contractor's Inspector shall be responsible for ensuring that all BMPs are installed in accordance with the contract or the manufacturers' recommendations. The Contractor's Inspector shall be capable of reading and interpreting these documents.
 - b. The Contractor's Inspector shall be familiar with product and structural BMPs. The Contractor's Inspector shall inspect, assess, and supervise the maintenance of erosion and sediment control BMPs to ensure compliance with the NPDES Construction Storm Water General Permit while preserving BMP functionality.
5. Payment for project inspection is subsidiary to items that direct payment is made.

**ENVIRONMENTAL COMMITMENT ENFORCEMENT
(2-1-1217)**

A. General

1. This specification establishes payment and disincentive assessment for the Contractor's performance in complying with Contract Environmental Commitments.
2. Deficiencies are described but not limited to:
 - a. Failure to install pollution prevention control BMPs as work progresses or as described in the SWPPP.
 - b. Failure to maintain existing pollution prevention control BMPs.

- c. Failure to remove non-functioning pollution prevention control BMPs.
- d. Failure to comply with USACE Section 404 Permit requirements.
- e. Failure to comply with NPDES Construction Storm Water General Permit requirements.
- f. Failure to comply with all applicable statutes relating to pollution of the waters of the state.
- g. Exceeding the maximum exposed surface area for excavation of 18 Acres without written request for permission and written approval.
- h. Failure to comply with wildlife species specific conservation conditions.
- i. Failure to comply with the Contract.
- j. Failure to comply with the Engineers directives.

B. SWPPP Deficiency Notification

1. The Engineer will document and direct the Contractor to correct deficiencies.
2.
 - a. The Contractor shall commence correcting deficiencies, provide adequate equipment and personnel, and diligently pursue correcting deficiencies without cessation until all deficiencies have been corrected.
 - b. The count of Working Days and/or Calendar Days will continue during the time period that corrective work is being performed.
 - c. Delays to the project as a result of the Contractor conducting corrective actions for the Contract Environmental Commitments will not constitute a valid reason for an extension of the contract time allowance.
3. Deficiencies shall be corrected within seven (7) calendar days of notification or within an approved extension. When deficiencies are not corrected within seven (7) calendar days or within an approved extension, the Engineer will make a disincentive assessment to the contract as stated herein.
4.
 - a. If soil, weather, or other conditions prevent the Contractor from completing the corrective actions within seven (7) calendar days, the Contractor shall notify the Engineer in writing. The Contractor's letter shall state the reasons preventing corrective action within the time allowed. The Contractor shall propose a written Corrective Action Plan within 48 hours. Corrective work shall continue while the Corrective Action Plan is developed. The Contractor's Corrective Action Plan must contain a course of action and a time frame for completion. If the reasons and the Corrective Action Plan are acceptable, the Engineer may extend the time in which to complete the corrective work.
 - b. The Contractor will be allowed to proceed with the plan as proposed without incurring a disincentive assessment. If all corrective work is

completed within the time allowance shown in the Notification or within an approved extension, a disincentive assessment will not be imposed upon the Contractor.

- c. Storm events or soil and weather conditions occurring on other projects, which interfere with a Contractor completing corrective actions on the project within seven (7) calendar days, will not be justification for a time extension to complete the corrective work.
5. If all corrective work identified in the Notification has not been completed at the end of the seventh (7th) calendar day after the Initial Notice Date or within an approved extension, a Shut-Down Notice will be issued on the eighth (8th) calendar day after the Initial Notice Date or on the calendar day following the last day of an approved extension.
 6. All operations shall cease as of the date and time cited in the Shut-Down Notice. The Contractor shall work, exclusively, on the deficiencies until all have been corrected or as directed by the Engineer. Upon issuance of the Shut-Down Notice, a disincentive of \$500.00 per deficiency per calendar day will be assessed thru the day the corrective work is completed, inclusive.
 7. The Engineer may require the Contractor to provide a written Procedures Plan that describes the process to prevent reoccurrence of deficiencies. The written Procedures Plan shall be provided within two (2) calendar days of the request. Failure to correct all deficiencies and provide a Procedures Plan may result in payments being withheld until such time that procedures are outlined.
 - a. Payment for preparing a written Procedures Plan is subsidiary to items that direct payment is made.

C. Storm Event Restoration – Incentive and Disincentive

1. The Department will pay “Storm Event Restoration - Incentive” when the Contractor completes the restoration work to eliminate the pollution prevention control deficiencies within seven (7) calendar days of Notification or within an approved extension. Multiple deficiencies may be included in one notification. If the restoration work has not been completed within seven (7) calendar days after the Initial Notice or within an approved extension, payment for the item of “Storm Event Restoration - Incentive” will not be made.
2. A storm event is defined as a storm exceeding 0.50 inch of rain in a 24 hour period.
3. The Department will notify the Contractor of pollution prevention control deficiencies.
4.
 - a. Payment for the item of “Storm Event Restoration - Incentive” may not be made when the Contractor is notified to correct pollution prevention devices not installed in accordance with the contract or the manufacturer’s recommended installation instructions.

5. If the restoration work is not completed within seven (7) calendar days or within an approved extension, a disincentive assessment of \$500.00 per deficiency per calendar day will be assessed. The disincentive assessment will begin on the eighth (8th) calendar day after the issuance of the Initial Notice Date or on the calendar day following the last day of an approved extension(s) and continue through the day that the restoration work is completed, inclusive.

D. Method of Measurement

1.
 - a. "Storm Event Restoration – Incentive" will be measured by the each upon completion of restoration of all deficiencies included in a notification within the allowed time and only one payment per notification is allowed when multiple deficiencies are included on the notification.
 - b. If deficiencies from multiple notifications are restored during the same restoration operation, only one (1) incentive is eligible for payment.
 - c. If multiple notifications are the result of successive storm events and deficiencies are transferred to ensuing notifications, incentive payment is only eligible for the latest notification.
2. "Storm Event Restoration – Disincentive" will be measured by the calendar day in accordance with Paragraph C.5. above.

E. Basis of Payment

- | | | |
|----|--|-----------------|
| 1. | Pay Item | Pay Unit |
| | Storm Event Restoration – Incentive | Each |
| | Storm Event Restoration – Disincentive | Calendar Day |
2. All equipment, materials, etc. used in the restoration work will be paid for in accordance with Division 800 of the Standard Specifications.
 3. Payment is full compensation for all other incidentals required to complete the restoration work included in the notification within the allowed time.

F. Environmental Commitments – Contractor Compliance

1. To provide payment for all plans, inspections, surveys, reports, travel, qualified inspection person's, carrion removal, and any other subsidiary activities for the work of implementing threatened and endangered species commitments, temporary erosion control or any other environmental commitments prescribed in the contract.
2. Multiple visits to the project may be required to comply with environmental commitments prescribed in the contract.

G. Method of Measurement

1. No measurement is required.

H. Basis of Payment

- | | | |
|----|--|-----------------------------|
| 1. | Pay Item
Environmental Commitments – Contractor Compliance | Pay Unit
Lump Sum |
|----|--|-----------------------------|
2. Partial payments will be made as follows:
 - a. The Department will pay 50 percent of the total amount bid for the item Environmental Commitments – Contractor Compliance within seven (7) calendar days after the Notice to Proceed Date.
 - b. Upon completion of 50 percent of the Original Contract Amount, the Department will pay 30 percent of the amount bid for the item Environmental Commitments – Contractor Compliance.
 - c. Upon completion of 75 percent of the Original Contract Amount, the Department will pay the remaining 20 percent of the amount bid for the item Environmental Commitments – Contractor Compliance.
 - d. Failure to comply with any or all of the contract requirements, included for payment under the item of Environmental Commitments – Contractor Compliance, will preclude all payment for the item, including any previous payment.
 3. Payment is full compensation for all work prescribed in the contract.

I. Immediate Action Deficiencies

1. Deficiencies that pose an imminent threat to the environment are considered an emergency situation. These deficiencies will be identified in the Immediate Action Deficiencies Section of the Environmental Commitment Deficiency Notification Form. The corrective work for Immediate Action Deficiencies shall begin immediately and continue without cessation until completed.
2. The Engineer will issue a shut-down notice. All work on the contract shall cease until the corrective work has been completed. The Engineer may allow the Contractor to continue working in areas unaffected by the Immediate Action Deficiency, provided corrective actions are being actively performed on the deficiency.
3. Immediate Action Deficiencies are not eligible for an incentive payment.
4. The Contractor will be assessed a disincentive assessment of \$1,000.00 per deficiency per calendar day for failure to begin corrective actions or failing to continue to completion as directed by the Engineer or by the regulatory agency with jurisdiction.
5. Examples of Immediate Action Deficiencies include but are not limited to:
 - a. Threatened & Endangered Species habitat protection deficiencies
 - b. USACE Section 404 Permit Noncompliance

- c. Petroleum Spills/Tank Leakage
- d. Hazardous Material Spills

J. Rights Reserved

1. The Department reserves the right to initiate and perform corrective action on any deficiencies which result from the Contractors' actions, inactions, or for failure to comply with the NPDES Construction Stormwater General Permit, USACE Section 404 Permit, or any other applicable permit.
2. The Contractor shall be liable to the Department for any and all costs incurred by the Department for corrective actions taken by the Department.
3. It is expressly understood that the provisions of this specification shall not relieve the Contractor of their responsibilities nor shall it relieve the Surety of its obligation for and concerning any just claim.
4. The Contractor shall indemnify and save harmless the Department and all of its representatives from any and all actions or claims brought because of the Contractor's actions, inactions, or for failure to comply with the NPDES Construction Storm Water General Permit, USACE Section 404 Permit, or any other applicable permit.

**HAZARDOUS MATERIALS MANAGEMENT
(2-1-1217)**

Description

This work shall consist of minimizing the exposure of the environment, including waters of the state, to hazardous materials. This specification also includes the requirements for clean-up of releases of hazardous materials.

Material Requirements

1. Prior to beginning work on the project, the Contractor shall prepare a Spill Prevention and Control Plan (SPCP) that clearly states measures to prevent a spill, contain a spill, clean up a spill, dispose of contaminated materials and train personnel to prevent and control spills. The plan shall include the notification contacts, as well as the processes and timeframes to address the situation in the event that a spill occurs. The following shall be included in the plan:
 - a. A site plan showing locations for loading of equipment and materials, storage of equipment and materials, equipment fueling and wash areas, portable toilet locations and waste disposal areas.
 - b. Descriptions of the following that may be used on projects:
 - i. Best Management Practices (BMPs) for secondary containment.

- ii. Description of spill response equipment and materials, including safety and clean up equipment.
 - iii. Preventative inspection and maintenance techniques for equipment to minimize leaks.
 - iv. Procedures for filling tanks and equipment to prevent spills.
 - v. Procedures for containing, diverting, isolating and cleaning up a spill.
 - vi. Procedures and BMPs to be administered at bridge and culvert sites to ensure that hazardous materials do not runoff.
 - (1) When water is present, immediate action to contain and remediate a spill is required.
 - (2) The Contractor shall notify the NDOT Project Manager and NDEQ upon release of any quantity of material to waters of the state. The NDOT Project Manager will notify the NDOT Environmental Section upon notification of a release.
 - vii. Spill training agenda and materials for the Contractor's staff and subcontractors.
- c. Identify individuals responsible for implementing the plan.
 - d. Specify how and when to notify appropriate authorities such as Nebraska Department of Environmental Quality and Nebraska State Patrol.
2. The Contractor shall provide and maintain a spill kit with appropriate materials to clean up minor spills on site as described in the Spill Prevention and Control Plan. A minor spill is defined as a release that is less than the reportable quantity for a given material and not entering waters of the state.
 3. Material Safety Data Sheets (MSDS) shall be maintained on site for all hazardous materials being used or stored for the project. The MSDS Sheets shall contain reportable quantities and spill response information.

Construction Methods

1. The Contractor shall store paints, solvents, pesticides, petroleum products, and other hazardous materials in areas with secondary containment.
2. Hazardous materials storage, including portable toilets, shall be restricted to specific areas away from:
 - a. vehicular traffic
 - b. restricted areas shown on the plans
 - c. waters of the state, including wetlands (50 feet minimum distance)

- d. Wellhead Protection Areas, unless designated in a Wellhead Protection Plan that has been approved by the local authority.
3. The Contractor shall inspect hazardous material containers weekly to ensure that all containers are clearly identified and that no leaks are present.
4. The Contractor shall inspect the site weekly to ensure that cleanup procedures are posted and that a spill kit is adequately stocked and readily available.
5. The Contractor shall verify and update the SPCP site maps as necessary during inspections to accommodate changes in the site.
6. A spill kit shall be readily available, in close proximity and appropriately stocked when applying petroleum based or other hazardous materials to bridge and culvert sites.
7. The Contractor shall develop, implement and maintain a training program regarding hazardous materials management. Training of the Contractor's staff and subcontractors shall be conducted to ensure that workers are knowledgeable of the procedures, materials and equipment outlined in the SPCP. The Contractor shall maintain a database of individuals that have been trained.
 - a. Specific hazardous materials and their handling procedures shall be discussed during safety briefings.
8. The Contractor shall maintain and provide to the Project Manager, upon request, a record of all spills occurring on site. This record shall include:
 - a. The circumstances leading to the spill
 - b. The date of the release
 - c. Measures taken to resolve the incident
 - d. Measures taken to prevent a recurrence
9. The Contractor shall follow NDEQ notification procedures for all spills in excess of a reportable quantity as defined by NDEQ Title 126 or the products MSDS Sheets. The NDOT Project Manager will notify the NDOT Environmental Section.
10. The Contractor shall follow all local, state and federal regulations associated with the release and/or cleanup, including disposal of the hazardous material.

Method of Measurement and Basis of Payment

1. Direct payment will not be made for work associated with Hazardous Materials Management, but is considered subsidiary to the items for which direct payment.
2. The Contractor shall solely bear all penalties and costs associate with the containment, cleanup, remediation and disposal of material associated with a spill.

**ACCEPTANCE TESTING OF SOILS BY USE OF THE LIGHT WEIGHT
DEFLECTOMETER (LWD) SCOPE
(2-2-1217)**

This test method covers the in-place measurement of deflection and moisture content of Class III embankments, subgrade preparation, granular fill and backfill for acceptance testing on Nebraska Department of Transportation Projects. Refer to Subsection 205.03 of the NDOT Standard Specifications for Highway Construction for a definition of Class III embankments. Refer to NDOT Test Method T 2835 for the proper operation of the LWD.

The deflection test measurement shall be the average measured deflection of the fourth, fifth, and sixth drops of the falling weight of the LWD. The first three drops are to be used to seat the LWD.

The Deflection Target Value (DTV) is the deflection value of each soil determined by using a test strip or from correlation with the Nebraska Group Index for an individual Soil.

Option 1

A. Determination of DTV using a Test Strip

1. A test strip shall be constructed for each soil type to determine the deflection target value.
2. A new test strip shall be constructed when there is an observed change in material or as determined by the Engineer.
3. The test strip dimensions for roadway embankment and subgrades shall have a minimum length of 200 feet and a width equal to the embankment or roadway. The total thickness shall be no less than 6 inches for roadway subgrade and no less than 1 foot and no more than 3 feet for roadway embankment.
4. The test strip dimensions for trenches, culverts, and structures shall have a minimum length of 10 feet and a width equal to that of the excavation. The total thickness shall be no less than 1 foot and no more than 3 feet.
5. The optimum moisture of fine grained soils shall either be determined in the NDOT Branch Lab or Central Lab, and shall be based on a correlation with the Plastic Limit or determined from AASHTO T-99. A 10-lb sample of proposed material shall be submitted to the NDOT Branch Lab or Central Lab a minimum of 14 days prior to grading operations.
6. The moisture content for granular soils shall be "as necessary" to achieve proper compaction.
7. The moisture content limits of the soil shall follow the requirements provided in Table 1.
8. The test strip area construction shall be incidental to the embankment construction.
9. The testing rate during the test strip construction is provided in Table 2.

Table 1 - Moisture Requirements

Location	Soil Type	Depth Below Finished Subgrade	Minimum %	Maximum %
Soil materials receiving concrete pavement	Silt – Clay Silt- Clay Granular	Upper 3 feet Greater than 3 feet All Depths	Opt. -3 Opt. -3 **	Opt. +2 Opt. +2 **
Soil materials receiving flexible pavement	Silt – Clay Silt- Clay Granular	Upper 3 feet Greater than 3 feet All Depths	Opt. -2 Opt. -3 **	Opt. +1 Opt. +2 **
Soil materials receiving gravel surfacing	All materials	All Depths	**	**
Subgrade prep. Shoulder subgrade prep (concrete pavement)	Silt – Clay Granular	The upper 6 inches of subgrade soil	Opt. -3 **	Opt +2 **
Subgrade prep. Shoulder subgrade prep (flexible pavement)	Silt – Clay Granular	The upper 6 inches of subgrade soil	Opt. -2 **	Opt +1 **
Stabilized Subgrade	-	-	See Specifications	
Granular Structural Fill (MSE Walls, bridges, culverts, et.)	Granular	All Depths	**	**

** Moisture as necessary to obtain proper compaction. The moisture target value for granular materials shall be established in the field by the Contractor during the compaction process. Once established the target moisture shall not vary by more than $\pm 2\%$.

Table 2 - Test Strip Testing Rate

Material Location	Minimum Testing Rate
Roadway embankment and subgrade	3 tests/ pass*
Trenches, culverts, and miscellaneous structures	1 test / pass*

* Number of passes with compaction equipment as described in paragraph 13c of Subsection 205.03 of the NDOT Standard Specifications for Highway Construction.

B. Test Strip Construction and Testing

1. Prior to placing the fill material for the test strip, the subgrade shall be scarified and re-compacted.
2. The fill material shall be placed with a lift thickness no greater than 8 inches uncompacted.
3. The test strip shall be constructed with uniform material and moisture content, and compaction; until it meets the requirements of numbers 3 or 4 of Section A of this provision.
4. The deflection target value is obtained when:
 - i. The moisture content is within the acceptable range.

- ii. The average of the deflection test measurements for three consecutive passes of compaction equipment does not change by more than 10% with additional compaction. The DTV shall be based on the lowest average deflection test measurement from these passes.
- 5. A 10-lb sample of the test strip material shall be submitted to the NDOT Branch Lab or Materials and Research Soil Lab for index testing.
- 6. The DTV shall be re-evaluated when:
 - i. Deflection test measurements are consistently less than the DTV. (3 out of 5 consecutive deflection test measurements are less than 0.80 of the DTV).
 - ii. Failing test results are consistently occurring and adequate compaction is observed.

Option 2

C. Determination of Deflection Target Values based on the Nebraska Group Index (NGI)

- 1. Prior to construction a 10-lb bag of representative material shall be submitted to the nearest NDOT Branch Lab or Materials and Research Soil Lab for each different soil type no less than 21 days prior to grading operations.
- 2. From the laboratory testing NDOT will determine the Nebraska Group Index (NGI) for each soil type submitted and provide a correlated minimum DTV and optimum moisture content.
- 3. If no correlation data is available for an individual NGI, a test strip shall be used to determine the DTV as discussed in parts A and B in this provision.
- 4. The DTV shall be re-evaluated when:
 - i. Deflection test measurements are consistently less than the DTV. (More than 20% of the deflection test measurements are less than 0.80 of the DTV).
 - ii. Failing test results are consistently occurring and adequate compaction is observed.

Acceptance Testing

- 1. The Deflection Target Value for use as acceptance testing shall be:
 - DTV \leq 1.10 x average deflection value determined from Option 1, Part B, of this provision
 - DTV \leq Correlated DTV determined from the NGI correlation, Option 2, Part C

2. The testing frequency for moisture and deflection shall follow the NDOT Materials Sampling Guide.
3. The moisture content of soil shall be performed using NDOT's approved equipment and methods. Approved equipment includes: 1) hot plates, stove, or microwave, 2) Speedy Moisture Method, or 3) Laboratory oven method.
4. Moisture content results shall be reported to the nearest tenth of a percent.

WORK ZONE TRAFFIC CONTROL SIGNS (4-3-1217)

The Department has adopted the FHWA 2009 Manual of Uniform Traffic Control (MUTCD) and the 2011 Nebraska Supplement to the MUTCD as the official guidance for work zone traffic control signs. Many work zone traffic control signs have been revised, redesigned, or replaced in the 2009 MUTCD (and 2011 Nebraska Supplement). Accordingly, all work zone signs shall comply with the following:

- 1 - All signs, regardless of age, shall meet the design standards of the 2009 MUTCD (and 2011 Nebraska Supplement).

WET REFLECTIVE THERMOPLASTIC PAVEMENT MARKING, GROOVED (4-7-1217)

I. Description

This work shall consist of furnishing and installing wet night retroreflective thermoplastic pavement markings in accordance with this provision and in conformance to the dimensions and lines shown on the plans or established by the Engineer.

This specification covers wet reflective thermoplastic materials suitable for use as reflective pavement markings on asphalt pavements. A manufacturer recommended heat source fuses the markings to the asphalt pavements. Glass beads shall be pre-mixed into the material furnished. Both glass beads and wet beads shall be applied to the surface either before or after fusion to the pavement. Upon cooling, the material produces an adherent reflectorized marking of specified thickness and width, capable of resisting deformation by traffic.

The Contractor shall field verify the pavement marking quantities required for the project prior to purchasing materials. The Department will not be held responsible for the Contractor's shortage or surplus of material. The Contractor's verification of quantities and purchasing material shall not delay the project or the installation of pavement marking when required.

The thermoplastic pavement marking shall be applied in grooves cut into the surfacing. The grooves shall be made in a single pass dry cut; the equipment used shall be self-vacuuming and leave the cut groove ready for thermoplastic pavement marking

application. The equipment and method used shall be approved by the thermoplastic pavement marking manufacturer. The thermoplastic pavement marking shall be applied in the grooves the same day as the cut. Grooves shall be clean and dry prior to thermoplastic pavement marking application. All conflicting pavement markings which remain after application of the thermoplastic pavement markings shall be removed. The removal of conflicting, pre-existing temporary or permanent pavement marking shall be paid for with the appropriate removal pay item. The removal of conflicting temporary or permanent pavement marking placed as part of this work shall be at no cost to the Department.

- Groove width: pavement marking width + 1 inch to 2 inch max
- Groove depth: per manufacturer’s recommendations
- Groove length: full length of marking + minimum required grooving transition
- Groove position: 2 inches off of joint line (per plan)

Grooving of the surfacing shall be performed in accordance with the thermoplastic manufacturer’s recommendations. Grooving the surfacing shall not be measured and paid for but shall be considered subsidiary to “Wet Reflective Thermoplastic Pavement Marking, Grooved”.

II. Requirements

a. General

- (1) Provide the material in white and/or yellow as specified.
- (2) Provide material with a minimum thickness of 0.1 inch as supplied by the manufacturer.
- (3) Provide material that is resistant to deterioration due to exposure to sunlight, water, oil, gasoline, salt, or adverse weather conditions.
- (4) After application, the material must exhibit no appreciable deformation or discoloration, remain tack free, and not lift from the pavement under normal traffic conditions within a road temperature range of 20° to 150°F.
- (5) Provide material that is capable of conforming to pavement contours, breaks, and faults through the action of traffic at normal pavement temperatures.

b. Color

Provide yellow material that meets the minimum chromaticity coordinates in **TABLE 1**.

TABLE 1: MINIMUM CHROMATICITY COORDINATES FOR YELLOW				
X	.470	.510	.485	.530
Y	.455	.485	.425	.456

c. Retroreflectivity

Required initial retroreflectance values are shown in the table below. Typical retroreflectivity is determined as the average of many readings (mcd(ft-2)(fc-1)) metric equivalent (mcd(m-2)(lux-1)) as described below.

TABLE 2: RETROREFLECTIVITY REQUIREMENTS (mcd(ft²)(fc-1))		
	White	Yellow
Dry (ASTM E1710)	400	325
Wet Recovery (ASTM E2177)	350	275
Wet Continuous (ASTM E2832)	100	75

- (1) Some reasonable variance should be expected (for example, application on very rough road surfaces or differences in glass beads).
- (2) The initial retroreflectance value of a single installation or unit of work shall be the average value determined according to the measurement and sampling procedures outlined in ASTM D7585, using a 30-meter (98.4 feet) retroreflectometer, except as modified below. The 30-meter retroreflectometer shall measure the coefficient of retroreflected luminance, R_L at an observation angle of 1.05 degrees and an entrance angle of 88.76 degrees. R_L shall be expressed in units of millicandelas per square foot per foot-candle [mcd(ft²)(fc⁻¹)]. The metric equivalent shall be expressed in units of millicandelas per square meter per lux [mcd(m²)(lux⁻¹)].
- (3) The initial retroreflectance values of the pavement marking shall be measured no sooner than 48 hours after application, but not later than 30 days after application. The Contractor shall provide an acceptable 30-meter retroreflectometer to use on the project (the retroreflectometer will remain the property of the Contractor). The Contractor will take measurements in the presence of the Engineer. Prior to taking measurements, the Contractor shall calibrate the retroreflectometer according to the manufacturer's requirements.

Measurements will be taken at equally spaced evaluation sections located by the Engineer. One evaluation section is required every 3 miles along a segment. If the last evaluation section is less than 1.5 miles, it shall be combined with the preceding section.

The evaluation sections shall be at least 400 ft. in length and have a minimum of 10 readings taken over the length of the section.

All measurements shall be made in the direction of travel. On centerlines of undivided highways, measurements shall be taken in both directions in each location and averaged for one measurement.

These measurements shall be taken for each color line in the evaluation section.

The Department will do verification testing on the evaluation section. When the average of the readings for an evaluation section fall below the

minimum, the entire section represented by those readings will be further evaluated by the Engineer and may be subject to removal and replacement.

- (4) The Department may elect to determine wet retroreflectance values measured under a “condition of continuous wetting” (simulated rain) in accordance with ASTM E2832. To reduce variability between measurements, the test method shall be performed in a controlled laboratory environment while the marking is positioned with a 3 to 5 degree lateral slope. Measurements shall be reported as the average of the minimum of three locations. Samples of the completed finished product shall be applied to flat panels during application and brought back to the lab for testing. When such samples are taken, the Department will furnish the panels.

d. Dimensions

The pavement markings shall be placed only on properly prepared surfaces and at the widths and patterns as designated in the contract. The markings shall be applied in accordance with the “Manual on Uniform Traffic Control Devices” and in accordance with the Engineer’s plans.

Any markings that are found to be 0.5 inches less than the width shown in the plans shall be removed and replaced by the Contractor.

e. Thermoplastic Material and Premix Beads

- (1) Provide thermoplastic material that complies with AASHTO M 249 with exception of the relevant differences due to the material being supplied in a preformed state.
- (2) All pigments must be heavy metal free, including, but not restricted to lead, cadmium, and mercury.

f. Glass Beads for Drop-on Application

Provide glass beads that are specifically manufactured to be compatible with the thermoplastic system, and comply with AASHTO M 247, Type I.

g. Wet Reflective Media

Provide wet reflective media approved by the manufacturer. The wet reflective media that qualify for use are shown in the NDOT Approved Products List.

III. Test Methods

- a. Thermoplastic Material and Premix Beads. AASHTO T 250**
- b. Glass Beads for Drop-On Application. AASHTO M 247**

IV. Observation Period

Following initial completion of all pavement marking, there will be a 180-day observation period before final acceptance. During the observation period, the Contractor, at no expense to the Department of Transportation, shall replace any markings that the Engineer determines are not performing satisfactorily due to defective materials and/or workmanship in manufacture and/or application. At the end of the observation period the minimum required retention percentage for marking installed shall be 90%.

Determination of Percentage Retained - The percentage retained shall be calculated as the nominal area of the strip less the area of loss divided by the nominal area and expressed as a percentage of the nominal area. A claim, made by the State against the Contractor, shall be submitted to the Contractor in writing within 30 days after the 180-day observation period. When such a claim is made prior to August 1, the replacement material shall be installed during that same construction season. Replacement material for any claim after August 1 shall be installed prior to June 1 of the following year. Marking replacement shall be performed in accordance with the requirements specified herein for the initial application, including but not limited to surface cleaning, sealer application, etc.

Final acceptance of all marking will include an inspection of the appearance of the markings during daylight and darkness. Any markings that fail to have a satisfactory appearance during either period, as determined by the Engineer, shall be reapplied at no expense to the Department of Transportation.

Final acceptance of the pavement marking will be: (1) 180 days after the initial completion of all work, or (2) upon completion of all corrective work, whichever occurs last.

V. Certification of Compliance

The Contractor shall furnish a manufacturer's certification that the material complies with the provisions of this specification.

VI. Contract Units and Basis for Payment

- a. Linear pavement markings will be measured in linear feet complete-in-place for the width specified.

Subsection 423.05 of the 2007 Standard Specifications is amended to include the item: "Wet Reflective Thermoplastic Pavement Marking, Grooved". The price shall be full compensation for grooving the pavement surface, furnishing and applying all markings, and for all materials, labor, tools, equipment and incidentals necessary to complete the work.

Payment will be made under:

Pay Item	Pay Unit
____ Wet Reflective Thermoplastic Pavement Marking, Grooved	Linear Feet

PERMANENT PAVEMENT MARKING

Section 423 in the Standard Specifications is amended to provide that for the items “ ___ Permanent Pavement Marking” the following materials may be used.

I Concrete Roadways

For pavement markings being placed on concrete surfaces, “Preformed Pavement Marking, Type 4, Grooved”, “Preformed Pavement Marking, Thermoplastic”, or “Polyurea, Grooved” may be used. Approved preformed pavement markings are shown on the NDOT Approved Products List. The material used shall be installed in accordance with the manufacturer’s specifications.

II Asphalt Roadways

For pavement markings being placed on asphalt surfaces, “Preformed Pavement Marking, Type 4, Grooved”, “Preformed Pavement Marking, Thermoplastic”, “Thermoplastic, Grooved”, or “Polyurea, Grooved” may be used. Approved preformed pavement markings are shown on the NDOT Approved Products List. The material used shall be installed in accordance with the manufacturer’s specifications.

Paragraph 1. of Subsection 423.05 is amended to include the following:

Pay Item	Pay Unit
___ Permanent Pavement Marking	Linear Foot (LF)
___ Permanent Pavement Marking	Each (ea)

Regardless of the material used it shall be measured and paid for as “ ___ Permanent Pavement Marking”.

COLD MILLING CLASS 3

Paragraph 8.a. of Subsection 510.04 of the Standard Specifications is void and superseded by the following:

Salvaged material produced on this project is the property of the State, but shall be furnished for use on this project at no cost to the Contractor. Approximately 350 tons of excess salvaged material shall be stockpiled at a site provided by the State. The State provided stockpile site is located at the NDOT Bridgeport State Maintenance Yard. Any remaining salvaged bituminous material produced from the cold milling operation, not used in production of asphaltic concrete on the project or stockpiled as shown above, shall become the property of the Contractor and removed from the project.

Amend Subsection 510.05 of the Standard Specifications to provide for the measurement of Cold Milling Class 3 in equivalent stations. Equivalent stations are defined as being the actual number of square feet of milling divided by 4000 for Cold Milling Class 3.

ASPHALTIC CONCRETE PLACEMENT

The 1 inch Asphaltic Concrete Type SLX overlay shall be placed in one lift.

The three inch Asphaltic Concrete Type SLX overlay shall be placed in two 1-1/2 inch lifts.

POLYESTER GEOGRID-FABRIC COMPOSITE

1. Description

The work shall consist of furnishing and placing a polyester geogrid-fabric composite reinforcing material and PG Binder as shown in the plans, this specification, or as directed by the Engineer.

2. Material Requirements

The polyester geogrid-fabric composite shall consist of a planar structure formed by a regular network of integrally connected polymeric tensile elements strands with apertures and a light non-woven backing which serves as an installation aid. The polyester geogrid-fabric composite shall be mildew resistant, rot-proof and shall be recommended for use with PG binders, asphalt emulsions and mat temperatures of 325° F. **The minimum required temperature of the asphalt overlay is 284° F.** The PG binder application rate shall follow manufacturer recommendations.

Material Properties Property	Test Method	Specification
Aperture Size, inch	I.D. Calipered	1.5" x 1.5"
Tensile Strength, lb/ft*	ASTM D-6637	3425 x 3425 min.
Tensile Strength @3% Strain, lb/ft	ASTM D-6637	825 min.
Elongation at Break, %	ASTM D-6637	<12
Melting Point of Geogrid, °F	ASTM D-276	490 min.
Roll Width, ft		12.5 min.
Roll Length, ft		450 min.
*Machine Direction x Cross Machine Direction		

The PG Binder shall satisfy the type and application rate recommended by the polyester geogrid-fabric composite manufacturer. The use of polymer modified binders is allowed, but may complicate application.

The polyester geogrid-fabric composite shall be on NDOT Approved Products List for Polyester geogrid-fabric composite.

3. Equipment

The spooler shall have a suitable pipe which shall be inserted into the cardboard roll of the polyester geogrid-fabric composite to aid in support and spooling of the composite during placement. The spooler shall also be capable of being articulated so that the slope of the roll of the polyester geogrid-fabric composite matches the slope of the pavement during placement.

A multiple-wheel, pneumatic-tired roller with the tires on the front and back staggered so that they will cover the entire area over which the roller travels. The roller tires shall have wide, smooth treads. The tire pressure shall be no less than 60 psi with a pressure variance no more than 5 psi.

4. Construction Methods

Surface Preparation. The location where polyester geogrid-fabric composite is to be placed shall be dry, cleaned of dirt, dust or other deleterious material. Perform as needed base repairs and seal cracks wider than $\frac{1}{4}$ inch. The surface must be even to ensure that the polyester geogrid-fabric composite has full contact with the sublayer and that no voids are present. A leveling course may be required should irregularities be excessive.

Weather Restrictions. The polyester geogrid-fabric composite shall not be applied until the air temperature is above 50 F and rising. In addition the polyester geogrid-fabric composite shall not be applied when the temperature of the surface on which the material is to be placed is below 60F. Neither the PG Binder nor the polyester geogrid-fabric composite shall be placed when general weather conditions, in the opinion of the Engineer, are not suitable.

Application of PG Binder. The rate of PG Binder application must be sufficient to adhere the polyester geogrid-fabric composite and asphalt overlay to the existing surface. The Contractor shall provide the Engineer with the manufacturer's recommended application rate and temperature during the first day of production. Typical application rate are 0.08 to 0.10 gal/yd². Application rates may be increased for aged or deteriorated pavements. The Engineer may adjust the rate of application based on site conditions. The width of the PG Binder application shall be the width of the polyester geogrid-fabric composite plus two to six inches. At no time will traffic, except minimal construction traffic, be allowed on the applied PG Binder. The temperature of the PG binder shall be heated in accordance with Section 501 of the Standard Specifications at the time of application to ensure a uniform spray pattern. No dripping or skipping will be permitted. PG Binder spills shall be cleaned from the pavement surface to avoid flushing and possible movement of the composite.

Installation of Polyester Geogrid-Fabric Composite. The Contractor shall place the polyester geogrid-fabric composite according to the manufacturer's recommendations. The polyester geogrid-fabric composite shall be placed directly onto the PG Binder with the geotextile fabric facing down and the geogrid facing up. The duration of time from the application of PG Binder to the installation of the polyester geogrid-fabric composite shall not exceed fifteen minutes. The composite shall be installed taut, without folds or creases. The polyester geogrid-fabric composite shall be placed as shown in the plans. Overlap shall be 6 inches on roll edges and 10 inches at roll ends. Overlap the polyester geogrid-fabric composite in a shingle fashion so that the paving train does not lift the leading edge of the overlap. All overlaps (edges, ends, and curves) shall be sprayed with PG Binder between layers. Joints in asphalt pavement shall not coincide with overlaps in the rolls of polyester geogrid-fabric composite. Immediately after placement, the polyester geogrid-fabric composite shall be rolled with a pneumatic-tired roller to ensure a good bonding between the polyester geogrid-fabric composite and the roadway. At no time shall traffic, except minimal construction traffic, be allowed on the placed polyester geogrid-fabric composite. Turning of equipment shall be gradual and kept to a minimum to avoid damage to the polyester geogrid-fabric composite.

During initial phases of installation of polyester geogrid-fabric composite, a manufacturer's representative shall be available to provide adequate technical support, supervision, and instruction, to the point of resolution of any material or placement issues encountered. The

Contractor's forces shall install the polyester geogrid-fabric composite in accordance with the specifications and the directions of the representative. There will be no payment for the on-site technical representative.

Asphalt Placement. Asphalt placement shall be done without delay following the placement of the polyester geogrid-fabric composite.

Delivery, Storage, and Handling. The Contractor shall inspect the polyester geogrid-fabric composite rolls upon delivery to ensure that the proper material has been received. During all periods of shipment and storage, the polyester geogrid-fabric composite shall be wrapped in a protective poly wrap and not exposed to temperatures exceeding 150° F. During all periods of storage, the polyester geogrid-fabric composite shall not be exposed to direct sunlight prior to placement. General storage and handling of the polyester geogrid-fabric composite rolls shall be in accordance with procedures identified in ASTM D 4873. Product labels shall clearly show the manufacturer or supplier name, style name, and roll number.

5. Method of Measurement

Furnishing and applying the geogrid-fabric composite shall be measured by the square yard of completed and accepted geogrid surface. No allowance shall be made for overlapping at joints.

6. Basis of Payment

The work of furnishing and applying the geogrid-fabric composite measured as provided herein, will be paid for at the contract unit price per square yard for the item "GEOGRID-FABRIC COMPOSITE". This price shall be full compensation for all materials labor, equipment, tools, and incidentals necessary to complete the work.

The work of furnishing and applying Performance Graded Binder shall be measured in Tons applied.

Pay Item	Pay Unit
Geogrid-Fabric Composite	Square Yard

**TABULATION OF CORES
(FOR INFORMATION ONLY)**

Location: Distances in reference to center of "S" Street intersection.	Distanc e Ft. Rt. or Lt. of CL	Field Depth inches	Remarks Asphaltic Concrete = (AC) Soil Aggregate Base Course = (SABC) Portland Cement Concrete = (PCC)
76' back	15 Rt.	11.25 AC	Sandy SABC
182' back	15 Rt.	9.75 AC	Sandy SABC
279' back	17 Rt.	9.0 AC	Sandy SABC
400' back	16 Rt.	9.0 AC	Sandy SABC
77' ahead	21 Lt.	11.75 AC	Sandy SABC. In two pieces.
204' ahead	26 Lt.	11.75 AC	Sandy SABC. In two pieces.
305' ahead	25 Lt.	11.25 AC	Sandy SABC. In three pieces.
401' ahead	26 Lt.	10.0 AC	Sandy SABC. In pieces. Bottom 1.5" stripped out.
85' back	12 Lt.	8.25 AC / 5.5 PCC	Too deep. AC in two pieces.
38' ahead	12 Rt.	10.5 AC	SABC
38' ahead	7 Rt.	~7.0 AC, 3.0 solid / PCC below	~4" AC crumbled when pulled. Too deep to determine PCC depth.

CONCRETE PAVEMENT REPAIR

Paragraph 1. of Subsection 605.01 in the Standard Specifications is void and superseded by the following:

1. This work shall consist of repairing portland cement concrete pavement at the locations designated by the Engineer. The work shall include removing deteriorated concrete, disposing of the old concrete, preparation of the repair area, and furnishing, placing, finishing and curing the concrete.

Paragraph 5.c. of Subsection 605.04 in the Standard Specifications is void and superseded by the following:

- c. Class PR1-3500 or PR3-3500 concrete pavement repairs shall not be opened to traffic until testing shows that the last repair made in that section of roadway has a compressive strength of 3000 psi. This will be determined by use of Maturity Method or cylinders, at the discretion of the Engineer. Table 605.03 is a guide to the minimum time the PR-3500 concrete will reach a compressive strength of 3500 psi.

Subsection 605.04 is amended to include the following:

8. Asphaltic Concrete for Patching
 - a. The asphalt surface shall be milled after performing the pavement repair work, or as shown elsewhere in the contract.
 - b. If the Contractor elects to pour concrete to the top of the existing concrete and use asphaltic concrete to finish filling the repair area, it shall be temporary asphaltic concrete. Temporary asphalt cannot be left in place.
 - c. Temporary asphaltic concrete will be any asphaltic concrete approved by the Engineer. The material, placement, maintenance, removal and disposal of temporary asphaltic concrete will not be measured and paid for, but shall be considered subsidiary to the item "Concrete Pavement Repair, Type A, B, or C, Full Depth".

SEEDING

Subsection 801.02 in the Standard Specifications is amended to include the following:

Type "B"	Minimum Purity (%)	Broadcast Application Rate in lb. of Pure Live Seed/Acre	Approved Mech. Drill Application Rate in lb. of Pure Live Seed/Acre
Perennial ryegrass – Linn, Norlea, Amazon	85		8
Slender wheatgrass	85		6
Thickspike wheatgrass – Critana	85		4
Western wheatgrass – Arriba, Rodan, Rosana	85		6
Kentucky fescue	85		6
Blue grama – NE, KS, SD, CO, MN	30		2
Buffalograss – Bison, Sundancer, Cody, Texoka	80		5
Sideoats grama – Butte, Pierre	75		4
Sand lovegrass – Nebraska 27, native	90		0.75
Oats/wheat (wheat in the fall)	90		18

All seed shall be origin Nebraska, adjoining states, or as specified. A Contractor proposing to use a substitute variety, or origin shall submit for the Engineer's consideration a seed tag representing the seed which shows the variety, origin and analysis of the seed.

Rates of application of commercial inorganic fertilizer shall be:

	Rate of Application Per Acre (Minimum)
Available Nitrogen (N2) -----	19 or 36 lb.
Available Phosphoric Acid (P2O5) -----	92 or 96 lb.

Rate of application of granular sulphur coated urea fertilizer shall be:

Nitrogen (total available) -----	0 lb.
----------------------------------	-------

The Contractor may, at his option, apply granular urea formaldehyde in lieu of the sulphur coated urea fertilizer at the following rate:

Nitrogen (total available) -----	0 lb.
----------------------------------	-------

**COVERCROP SEEDING
(8-6-1217)**

Paragraph 3. of Subsection 802.02 in the Standard Specifications is void and superseded by the following:

Fertilizer is not required for covercrop seeding.

Paragraph 6. of Subsection 802.03 is void.

PERFORMANCE GRADED BINDER

The Performance Graded Binder to be used on this project shall be PG Binder 58V-34 supplied by a Certified Supplier.

**HYDRATED LIME FOR ASPHALT MIXTURES
(10-3-1217)**

1. General

Hydrated lime will be added to all aggregates (at the Contractor's option, limestone may be excluded) used for asphalt mixtures except Asphaltic Concrete used for Temporary Surfacing, and Asphaltic Concrete Type SPS, and SPL. Hydrated lime will be added to pre-moistened aggregates whether it is used directly into the mix or stockpiled for marinating purposes. The application of moisture and hydrated lime to the aggregates

along with equipment calibration and procedures to prevent any "dusting" shall be documented and approved in the Contractor's Quality Control (QC) Plan.

2. Material Requirements

The lime shall meet the chemical and physical properties defined in AASHTO M 303 for Type I - High calcium-hydrated lime, or meet the requirements of ASTM 1097 for Type S Hydrated Lime.

The hydrated lime being used, whether for mix design or plant mix production, shall be stored in an enclosed container and must be used within 90 days. Stockpiles marinating shall also be used within 90 days. Lime that is stored over 90 days in a protected storage silo environment may be submitted for chemical analysis to verify that it meets the specification for use in the mix.

Water shall conform to the requirements of Section 1005.

3. Construction

Prior to the addition of hydrated lime the aggregates shall have a minimum moisture content of 3% by weight of aggregate. The surface of the aggregate shall be uniformly dampened by water.

If additional moisture is required it shall be added at the entry end of an enclosed pug mill mixer and prior to the addition of hydrated lime.

Hydrated Lime shall be added at a rate of 1.25 percent by weight of virgin aggregate, including the weight of the limestone.

4. Equipment

The addition of lime shall be plant controlled, and blended with an enclosed twin-shaft pug mill with a production capacity rating that exceeds the aggregate feed rate. It shall be capable of effective mixing in the full range of asphaltic concrete production rates.

The pug mill set up shall be located in the system at a location where the mixed material can be readily inspected on a belt prior to entry into the drum.

The pug mill shall be designed such that the mixture of aggregate and hydrated lime is moved in a near horizontal direction (within 20 degrees of horizontal) by the mixing paddles without the aid of conveyor belts for a distance of at least three feet (900 mm). Mixing devices which permit the mixture of aggregate and hydrated lime to fall through the mixing blades onto a belt or chute are not acceptable.

A positive signal system and a limit switch device shall be installed in the plant at the point of introduction of the hydrated lime. The positive signal system shall be placed between a metering device and the drum plant, and utilized during production whereby an alarm is activated; alerting the plant that the hydrated lime is not being introduced into the mixture.

The hydrated lime storage silo shall have enough capacity for continuous production. The silo shall be replenished by pneumatic delivery from road tankers at a pressure that

will not create dusting. Hydrated lime will be dispensed from the silo into the pug mill by a conventional vane feeder or a load cell pod system.

The mechanism for adding moisture to the aggregate will be configured and located to insure that all virgin aggregate is uniformly coated with moisture prior to the lime application.

5. Sampling and Testing

Hydrated lime shall be certified by the supplier stating its compliance to the specifications.

A physical inventory of hydrated lime usage will be required during mix production. A daily silo inventory, noting "beginning weight", "weight added during the day's production", and "end of day weight", will be recorded and made available for review by the Engineer. When a weigh pod system is used, an accumulative accounting method shall be used to calculate and review lime addition rates throughout production. When calculations indicate a hydrated lime usage of ± 0.15 percent from the design percentage the Contractor shall assume the responsibility to cease production and recalibrate the system prior to resuming mix production. Any asphaltic concrete placed having 0.15 percent below the design percentage shall be removed and replaced at no cost.

The percent of moisture shall be determined and documented: 1) from belt samples or 2) from stockpile samples, a minimum of once per day.

6. Mixture QC and Verification Testing

During an ignition oven burn off, lime will combine with the sulfur in the binder and produce ash. Therefore, when mix containing hydrated lime is being designed and produced a correction factor to the ignition oven burn off result of +0.30% shall be used. This correction factor shall be added to the ignition oven binder content reading in order for the actual binder content to be determined.

7. Method of Measurement:

Hydrated Lime shall be measured for payment by the unit of each for each ton of hot mix asphalt used and incorporated into the project, or for State Maintenance Patching.

Water applied shall not be measured and paid for but shall be considered subsidiary to the item "Hydrated Lime/Warm Mix Asphalt".

8. Basis of Payment:

Lime, measured as provided herein and incorporated into the project, shall be paid for at the contract unit price per each for the item "Hydrated Lime/Warm Mix Asphalt". Lime measured as provided herein and used for State Maintenance Patching shall be paid for at the contract unit price per each for the item "Hydrated Lime/Warm Mix Asphalt for State Maintenance Patching". This price shall be full compensation for furnishing, delivering, hauling, storing, all labor, equipment, tools and incidentals necessary to complete the work.

HYDRATED LIME SLURRY FOR ASPHALT MIXTURES (10-3-1217)

1. **General** — The Contractor will have the option of using Hydrated Lime Slurry For Asphalt Mixtures or Hydrated Lime For Asphalt Mixtures. Hydrated lime slurry will be added to all aggregates (at the Contractor's option, limestone may be excluded) used for asphalt mixtures except Asphaltic Concrete used for Temporary Surfacing, and Asphaltic Concrete Type SPS and SPL. Hydrated lime slurry will be added to aggregates whether it is used directly into the mix or stockpiled for marinating purposes. The application of hydrated lime slurry to the aggregates along with equipment calibration and procedures shall be documented and approved in the Contractor's Quality Control (QC) Plan.
2. **Material Requirements** — The lime shall meet the chemical and physical properties defined in AASHTO M 303 for Type I - High calcium-hydrated lime, or meet the requirements of ASTM 1097 for Type S Hydrated Lime.

The dry hydrated lime being used, whether for mix design or plant mix production, shall be stored in an enclosed container and must be used within 90 days. Stockpiles marinating shall also be used within 90 days. Hydrated lime (dry or slurry) that is stored over 90 days in a protected storage silo or slurry tank may be submitted for chemical analysis to verify that it meets the specification for use in the mix.

Water shall conform to the requirements of Section 1005.

3. **Construction** — Hydrated Lime shall be added at a rate of 1.25 percent by weight of virgin aggregate, including the weight of the limestone.
4. **Equipment** — The addition of lime shall be plant controlled, and blended with an enclosed twin-shaft pug mill with a production capacity rating that exceeds the aggregate feed rate. It shall be capable of effective mixing in the full range of asphaltic concrete production rates.

The pug mill set up shall be located in the system at a location where the mixed material can be readily inspected on a belt prior to entry into the drum.

The pug mill shall be designed such that the mixture of aggregate and hydrated lime is moved in a near horizontal direction (within 20 degrees of horizontal) by the mixing paddles without the aid of conveyor belts for a distance of at least three feet (900 mm).

Mixing devices which permit the mixture of aggregate and hydrated lime to fall through the mixing blades onto a belt or chute are not acceptable.

A positive signal system and a limit switch device shall be installed in the plant at the point of introduction of the hydrated lime. The positive signal system shall be placed between a metering device and the drum plant, and utilized during production whereby an alarm is activated; alerting the plant that the hydrated lime is not being introduced into the mixture.

A minimum of two hydrated lime slurry tanks shall be used for blending and supply. Slurry shall be drawn for production from only one tank at a time. The hydrated lime slurry tanks shall have enough capacity for continuous production.

Hydrated lime slurry shall be dispensed from a slurry tank into the pug mill by a pressure regulated spray system having an electronic flow measurement system that has been calibrated to insure the proper application rates will be provided. Certificate of Calibration for the spray bar system should be provided by the Contractor with the calibration being performed by a third party every 12 months (minimum) or at the Engineer's request.

The electronic flow measurement system shall automatically record the flow rate of the lime slurry being fed to the pug mill. The data recorder system shall be capable of recording the flow rate (in gallons per minute) at intervals of not more than 5 minutes and shall have the capability of calculating the volume of lime slurry used each day, from each slurry tank, and shall be capable of printing a summary of the daily lime slurry usage for each tank. This printout of the daily lime slurry volumes shall be presented to the NDOT representative at the end of each day's production.

- 5. Blending and Supply Hydrated Lime Slurry** — The Contractor shall determine the target hydrated lime slurry concentration (percent solids) that will be used to produce the asphalt mixture. This target concentration value shall be provided to the Engineer prior to production of the asphalt mixture and shall not be less than 30 percent. The target concentration value shall not be modified without the approval of the Engineer. It is the Contractor's responsibility to control the concentration of the hydrated lime slurry.

Only valid weights of dry hydrated lime shall be added to the required quantity of water to provide uniform hydrated lime slurry having a dry solids content within ± 0.5 percent of the Contractor's target value. Water or dry hydrated lime shall not be added to a tank that is actively supplying hydrated lime slurry to the pug mill. Hydrated lime slurry shall not be drawn from a tank that is not completely blended in accordance with the manufacturer's recommendations.

The hydrated lime slurry in the active supply tank shall be agitated prior to and during production in accordance with the manufacturer's recommendations.

Dry hydrated lime shall be transferred at a pressure that will not create dusting.

- 5.1** If individual hydrated lime slurry tanks are dedicated to only blending or supply, then thoroughly mixed hydrated lime slurry may be added from the blending tank(s) to the supply tank during production, provided the concentrations are within ± 0.5 percent.
- 5.2** If the hydrated lime slurry tanks are used for both blending and supply, the tanks shall be plumbed such that hydrated lime slurry can be supplied to the pug mill from any of the blending/supply tanks without disruption of the slurry supply.
- 6. Sampling and Testing** — Hydrated lime shall be certified by the supplier stating its compliance to the specifications.

The concentration of the lime slurry shall be controlled within ± 0.5 percent of the target hydrated lime slurry concentration (percent solids). The concentration of the hydrated lime shall be determined in accordance with Section 6.1. It is the Contractor's responsibility to halt production to make adjustments when the concentrations fall out of compliance.

The concentration of the lime slurry shall be determined and recorded by the Contractor immediately following blending each batch of lime slurry for the project. These records shall include date and time of test, sample collection information, and the unit weight, temperature and concentration of slurry. These records shall be made available to the Engineer upon request.

A physical inventory of hydrated lime usage will be required during mix production. This inventory shall be used to verify the lime application rate, and for payment of the hydrated lime. The concentration of the lime slurry shall be determined and recorded by the Contractor at the beginning and at approximately the mid-point of each day's production. The hydrated lime slurry samples shall be collected from the supply line leading to the pug mill. These records shall include date and time of test, sample collection information, and the unit weight, temperature and concentration of slurry. These records shall be presented to the NDOT representative at the end of each day's production.

When calculations indicate that the application rate of "dry" hydrated lime to the aggregate is ± 0.15 percent from the design percentage the Contractor shall assume the responsibility to cease production and recalibrate the system prior to resuming mix production. Any asphaltic concrete placed having a "dry" hydrated lime application rate (applied to aggregate) of 0.15 percent below the design percentage shall be removed and replaced at no cost.

6.1 The Contractor shall determine the solids content (concentration) of the hydrated lime slurry using Table 1, Table 2 and the Slurry Worksheet. The Contractor shall provide and use the standard weight per 83.205-ml Gardner cup meeting the requirements of ASTM D 244.

After a batch of lime slurry has been produced, use the following procedures to verify that the intended percent solids have been achieved.

1. Fill a quart container 3/4 full with lime slurry. Samples can be taken from ports located at either end of the vessel. Do not use glass.
2. Weigh a dry, empty Gardner (WPG) cup and cover to the nearest 0.01 of a gram. Record this weight.
3. Shake the lime slurry sample well. Immediately fill the WPG cup.
4. Tap the WPG cup lightly on an immovable object to allow for the escape of air bubbles.
5. Slowly turn the cap of the WPG cup until it is completely seated. If the cover is pushed on quickly, lime slurry will squirt out through the hole in the center. Be sure to point the top of the WPG away from you (or others) while putting on the cap.
6. Hold the WPG cup by the top and bottom with thumb and forefinger. Be sure to cover the hole in the cap.

7. Rinse the WPG cup under running water to remove any lime from the outside of the cup.
 8. Dry the outside of the cup thoroughly.
 9. Weigh the dry, filled WPG cup to the nearest 0.01 of a gram. Record this weight.
 10. Promptly remove the cover, insert thermometer and record the temperature.
 11. Subtract the empty cup weight (from step 2) from the filled cup weight (step 9) and record the difference.
 12. Multiply the difference by 0.1. This number is the density (lbs./gallon) of the lime slurry. Record this number.
 13. Look up the temperature correction in Table 2 and record the value.
 14. Multiply the slurry density times the temperature correction value. This is the adjusted slurry density. Record the adjusted slurry density on the slurry worksheet.
 15. Find the nearest density to that recorded above on the "Slurry Solids Chart" on Table 1, Slurry Solids Chart - 24 degrees C. The corresponding number is the percent solids (concentration) of the lime slurry sample. Record on worksheet.
7. **Mixture QC and Verification Testing** — During an ignition oven burn off, lime will combine with the sulfur in the binder and produce ash. Therefore, when mix containing hydrated lime is being designed and produced a correction factor to the ignition oven burn off result of +0.30% shall be used. This correction factor shall be added to the ignition oven binder content reading in order for the actual binder content to be determined.
8. **Method of Measurement** — Hydrated Lime shall be measured for payment by the unit of each for each ton of hot mix asphalt used and incorporated into the project, or for State Maintenance Patching.
- Water applied shall not be measured and paid for but shall be considered subsidiary to the item "Hydrated Lime/Warm Mix Asphalt".
9. **Basis of Payment** — Lime, measured as provided herein and incorporated into the project, shall be paid for at the contract unit price per each for the item "Hydrated Lime/Warm Mix Asphalt". Lime measured as provided herein and used for State Maintenance Patching shall be paid for at the contract unit price per each for the item "Hydrated Lime/Warm Mix Asphalt for State Maintenance Patching". This price shall be full compensation for furnishing, delivering, hauling, storing, all labor, equipment, tools and incidentals necessary to complete the work.

Table 1, Page 1
Slurry Solids Chart – 24°C

Density lbs./gal.	Slurry Solids %	Density lbs./gal.	Slurry Solids %	Density lbs./gal.	Slurry Solids %	Density lbs./gal.	Slurry Solids %
9.108	15.1	9.402	20.1	9.715	25.1	10.050	30.1
9.114	15.2	9.406	20.2	9.722	25.2	10.057	30.2
9.120	15.3	9.414	20.3	9.728	25.3	10.064	30.3
9.128	15.4	9.420	20.4	9.735	25.4	10.071	30.4
9.131	15.5	9.426	20.5	9.741	25.5	10.078	30.5
9.137	15.6	9.433	20.6	9.748	25.6	10.085	30.6
9.143	15.7	9.439	20.7	9.755	25.7	10.092	30.7
9.148	15.8	9.445	20.8	9.761	25.8	10.099	30.8
9.154	15.9	9.451	20.9	9.768	25.9	10.106	30.9
9.160	16.0	9.457	21.0	9.774	26.0	10.113	31.0
9.166	16.1	9.463	21.1	9.781	26.1	10.120	31.1
9.171	16.2	9.469	21.2	9.787	26.2	10.127	31.2
9.177	16.3	9.476	21.3	9.794	26.3	10.134	31.3
9.183	16.4	9.482	21.4	9.800	26.4	10.141	31.4
9.189	16.5	9.488	21.5	9.807	26.5	10.148	31.5
9.195	16.6	9.494	21.6	9.814	26.6	10.155	31.6
9.200	16.7	9.500	21.7	9.820	26.7	10.163	31.7
9.206	16.8	9.506	21.8	9.827	26.8	10.170	31.8
9.212	16.9	9.513	21.9	9.833	26.9	10.177	31.9
9.218	17.0	9.519	22.0	9.840	27.0	10.184	32.0
9.224	17.1	9.525	22.1	9.847	27.1	10.191	32.1
9.230	17.2	9.531	22.2	9.853	27.2	10.198	32.2
9.235	17.3	9.538	22.3	9.860	27.3	10.205	32.3
9.241	17.4	9.544	22.4	9.867	27.4	10.212	32.4
9.247	17.5	9.550	22.5	9.873	27.5	10.220	32.5
9.253	17.6	9.556	22.6	9.880	27.6	10.227	32.6
9.259	17.7	9.563	22.7	9.887	27.7	10.234	32.7
9.265	17.8	9.569	22.8	9.894	27.8	10.241	32.8
9.271	17.9	9.575	22.9	9.900	27.9	10.248	32.9
9.277	18.0	9.581	23.0	9.907	28.0	10.255	33.0
9.282	18.1	9.588	23.1	9.914	28.1	10.263	33.1
9.288	18.2	9.594	23.2	9.920	28.2	10.270	33.2
9.294	18.3	9.600	23.3	9.927	28.3	10.277	33.3
9.300	18.4	9.607	23.4	9.934	28.4	10.284	33.4
9.306	18.5	9.613	23.5	9.941	28.5	10.292	33.5
9.312	18.6	9.619	23.6	2.948	28.6	10.299	33.6
9.318	18.7	9.626	23.7	9.954	28.7	10.306	33.7
9.324	18.8	9.632	23.8	9.961	28.8	10.314	33.8
9.330	18.9	9.638	23.9	9.968	28.9	10.321	33.9
9.336	19.0	9.645	24.0	9.975	29.0	10.328	34.0
9.342	19.1	9.651	24.1	9.982	29.1	10.335	34.1
9.348	19.2	9.658	24.2	9.988	29.2	10.343	34.2
9.354	19.3	9.664	24.3	9.995	29.3	10.350	34.3
9.360	19.4	9.670	24.4	10.002	29.4	10.358	34.4
9.366	19.5	9.677	24.5	10.009	29.5	10.365	34.5
9.372	19.6	9.683	24.6	10.016	29.6	10.372	34.6
9.378	19.7	9.690	24.7	10.023	29.7	10.380	34.7
9.384	19.8	9.696	24.8	10.030	29.8	10.387	34.8
9.390	19.9	9.703	24.9	10.037	29.9	10.394	34.9
9.396	20.0	9.709	25.0	10.044	30.0	10.402	35.0

Table 1, Page 2
Slurry Solids Chart – 24°C

Density lbs./gal.	Slurry Solids %	Density lbs./gal.	Slurry Solids %	Density lbs./gal.	Slurry Solids %	Density lbs./gal.	Slurry Solids %
10.409	35.1	10.795	40.1	11.210	45.1	11.658	50.1
10.417	35.2	10.803	40.2	11.218	45.2	11.667	50.2
10.424	35.3	10.811	40.3	11.227	45.3	11.677	50.3
10.432	35.4	10.819	40.4	11.236	45.4	11.686	50.4
10.439	35.5	10.827	40.5	11.244	45.5	11.695	50.5
10.447	35.6	10.835	40.6	11.253	45.6	11.705	50.6
10.454	35.7	10.843	40.7	11.262	45.7	11.714	50.7
10.462	35.8	10.851	40.8	11.270	45.8	11.724	50.8
10.469	35.9	10.859	40.9	11.279	45.9	11.733	50.9
10.477	36.0	10.867	41.0	11.288	46.0	11.743	51.0
10.484	36.1	10.875	41.1	11.297	46.1	11.752	51.1
10.492	36.2	10.883	41.2	11.305	46.2	11.762	51.2
10.499	36.3	10.892	41.3	11.314	46.3	11.771	51.3
10.507	36.4	10.900	41.4	11.323	46.4	11.781	51.4
10.514	36.5	10.908	41.5	11.332	46.5	11.790	51.5
10.522	36.6	10.916	41.6	11.341	46.6	11.800	51.6
10.530	36.7	10.924	41.7	11.349	46.7	11.809	51.7
10.537	36.8	10.932	41.8	11.358	46.8	11.819	51.8
10.545	36.9	10.941	41.9	11.367	46.9	11.828	51.9
10.552	37.0	10.949	42.0	11.376	47.0	11.838	52.0
10.560	37.1	10.957	42.1	11.385	47.1	11.848	52.1
10.568	37.2	10.965	42.2	11.394	47.2	11.857	52.2
10.575	37.3	10.974	42.3	11.403	47.3	11.867	52.3
10.583	37.4	10.982	42.4	11.412	47.4	11.877	52.4
10.591	37.5	10.990	42.5	11.421	47.5	11.886	52.5
10.599	37.6	10.998	42.6	11.430	47.6	11.896	52.6
10.606	37.7	11.007	42.7	11.439	47.7	11.906	52.7
10.614	37.8	11.015	42.8	11.447	47.8	11.915	52.8
10.622	37.9	11.023	42.9	11.456	47.9	11.925	52.9
10.629	38.0	11.032	43.0	11.465	48.0	11.935	53.0
10.637	38.1	11.040	43.1	11.475	48.1	11.945	53.1
10.645	38.2	11.048	43.2	11.484	48.2	11.954	53.2
10.653	38.3	11.057	43.3	11.493	48.3	11.964	53.3
10.661	38.4	11.065	43.4	11.502	48.4	11.974	53.4
10.668	38.5	11.074	43.5	11.511	48.5	11.984	53.5
10.676	38.6	11.082	43.6	11.520	48.6	11.994	53.6
10.684	38.7	11.090	43.7	11.529	48.7	12.004	53.7
10.692	38.8	11.099	43.8	11.538	48.8	12.014	53.8
10.700	38.9	11.107	43.9	11.547	48.9	12.023	53.9
10.707	39.0	11.116	44.0	11.556	49.0	12.033	54.0
10.715	39.1	11.124	44.1	11.566	49.1	12.043	54.1
10.723	39.2	11.133	44.2	11.575	49.2	12.053	54.2
10.731	39.3	11.141	44.3	11.584	49.3	12.063	54.3
10.739	39.4	11.150	44.4	11.593	49.4	12.073	54.4
10.747	39.5	11.158	44.5	11.602	49.5	12.083	54.5
10.755	39.6	11.167	44.6	11.612	49.6	12.093	54.6
10.763	39.7	11.175	44.7	11.621	49.7	12.103	54.7
10.771	39.8	11.184	44.8	11.630	49.8	12.113	54.8
10.779	39.9	11.193	44.9	11.639	49.9	12.123	54.9
10.787	40.0	11.201	45.0	11.649	50.0	12.134	55.0

Table 2
Correction Factor to Adjust Slurry Densities for Temperature

Temp (C)	Factor	Temp (C)	Factor
20	0.99927	61	1.01176
21	0.99944	62	1.01218
22	0.99962	63	1.01262
23	0.99981	64	1.01305
24	1.00000	65	1.01349
25	1.00002	66	1.01394
26	1.00041	67	1.01439
27	1.00063	68	1.01485
28	1.00085	69	1.01531
29	1.00109	70	1.01578
30	1.00132	71	1.01626
31	1.00157	72	1.01673
32	1.00182	73	1.01722
33	1.00208	74	1.01770
34	1.00234	75	1.01820
35	1.00261	76	1.01870
36	1.00289	77	1.01920
37	1.00318	78	1.01971
38	1.00347	79	1.02022
39	1.00376	80	1.02074
40	1.00407	81	1.02126
41	1.00438	82	1.02179
42	1.00469	83	1.02232
43	1.00501	84	1.02286
44	1.00534	85	1.02341
45	1.00567	86	1.02395
46	1.00601	87	1.02451
47	1.00635	88	1.02506
48	1.00670	89	1.02563
49	1.00706	90	1.02619
50	1.00742	91	1.02677
51	1.00779	92	1.02734
52	1.00816	93	1.02793
53	1.00854	94	1.02851
54	1.00892	95	1.02911
55	1.00931	96	1.02970
56	1.00970	97	1.03031
57	1.01010	98	1.03091
58	1.01051	99	1.03152
59	1.01092	100	1.03214
60	1.01134	101	1.03276

Slurry Worksheet

Date	Time	WPG Cup Weight Full Step (9)	WPG Cup Weight Empty (2)	Slurry Weight (Full-Empty) (11)	Slurry Density (Slurry Wt. x 0.10) (12)	Sample Temp. °C (10)	Temp. Correction Factor (Table 2) (13)	Adjust Density (Slurry Density x Temp. Corr. Factor) (14)	Percent Solids (Table 1)

**INCENTIVE PAYMENT FOR THE USE OF RECYCLED ASPHALTIC PAVEMENT
(RAP) FOR ASPHALTIC MIXTURES
(10-7-1217)**

General

This specification establishes a standard method for paying an incentive to use Recycled Asphaltic Pavement (RAP) in asphalt mixture types: SPH, SPS, SPR, SRM, SLX and LC. The intent of this specification is to provide an incentive for incorporating as much RAP into the asphalt mixtures as allowed by the respective mixture’s specification.

Method of Measurement

1. The RAP Incentive Payment shall be based on the actual total of asphalt production for the entire project. A RAP Incentive Payment shall be calculated for each eligible asphaltic concrete type.
2. The following formula will be used to calculate the “RAP Incentive Factor”.

$$\text{RAP Incentive Factor} = [(A-B) \div 100] \times C \times D$$

Where:

- A = State’s Established Percent Binder – based on gradation band.
- B = Actual Percentage of Binder – added to asphaltic mixture.
- C = Unit Bid price of Binder
- D = RAP Pay Factor

3. The State’s established percent binder values (‘A’ values) are as follows:

Asphaltic Concrete Types	‘A’ Value
SPH having 0.500-inch grading band	5.2% Binder
SPS, SPL, SPR and SPR (Fine)	5.2% Binder
SLX	5.5% Binder
SPH having 0.375-inch grading band	5.8% Binder
LC	6.2% Binder
SRM	4.8% Binder

Incentive payments will be made for only the mix types list in this table.

4. The actual percentage of binder added to the particular asphaltic mixture (‘B’ value) shall be calculated as follows:
 - B = (Actual Pay Tons of Binder ÷ Actual Pay Tons of Asphaltic Concrete) x 100
5. The Unit Bid Price of Binder (‘C’ value) is the established contract price for the performance graded binder type used to produce the mix for which the incentive is being calculated.

6. The RAP Pay Factor ('D' value) shall be as follows:

RAP Source	'D' Value
Contractor supplied RAP	0.50
State supplied RAP coming from an OFF -project source	0.35
* RAP coming from an ON -project source	0.15

* RAP coming from an **ON**-project source shall be completely utilized before allowing RAP from any other source to be used in the asphalt production. An ON-project source shall be considered any asphaltic material removed on the project.

7. Contractor supplied RAP and RAP supplied from either off-project or on-project sources shall be stored, handled and used separately. Incentive payments for RAP from these three source types shall be paid separately. The Contractor may propose a RAP consumption plan that will use multiple RAP sources concurrently and will follow the utilization hierarchy (as detailed above) upon the completion of the project.
8. The Contractor has sole responsibility for determining the quality, quantity, and uniformity of the RAP material. The maintenance of any stockpiles and processing of the RAP material shall also be the sole responsibility of the Contractor.

Basis of Payment

- | | | |
|----|--|------------------------------|
| 1. | Pay Item
RAP Incentive Payment _____ | Pay Unit
Each (ea) |
|----|--|------------------------------|
2. The overall RAP Incentive Payments shall be full compensation for all RAP materials and all hauling, handling and processing necessary to complete the work described in this section.
3. The overall RAP Incentive Payments – for each eligible mix type and/or RAP source – shall be the RAP Incentive Factor multiplied by the total accepted tons of asphaltic concrete in which the RAP was incorporated.
4. RAP Incentive Payment is paid for as an “established” contract unit price which is shown in the bid proposal “Schedule of Items”.
5. The actual quantity for RAP Incentive Payment will be calculated based on the Method of Measurement stated above in this provision.

**BITUMINOUS LIQUID COMPOUNDS FOR CURING CONCRETE
(10-8-1217)**

Subsection 1013.02 in the Standard Specifications is amended to include the following:

2. The Contractor has the option of using bituminous tack coat. The tack coat shall conform to all requirements of Section 504.

SUPERPAVE ASPHALTIC CONCRETE

Paragraph 8.d. of Subsection 1028.03 in the Standard Specifications is void and superseded by the following:

- d. Normally, 1 (one) sample for determination of density will be taken from each subplot at locations determined by the Engineer.

Table 1028.18 (SLX) in Subsection 1028.03 is void and superseded by the following:

Table 1028.18 (SLX)
Acceptance Schedule
Air Voids - N_{des}

Air voids test results for Asphaltic Concrete Type SLX	Pay Factor	
	Moving average of four	Single test
Less than 0.5%	50% or Reject	50% or Reject
0.5% to 0.9%	50% or Reject	50%
1.0% to 1.4%	50% or Reject	95%
1.5% to 1.9%	90%	95%
2.0% to 2.4%	100%	100%
2.5% to 3.5%	102%	104%
3.6% to 4.0%	100%	100%
4.1% to 4.5%	95%	95%
4.6% to 5.0%	90%	95%
5.1% to 5.5%	50% or Reject	90%
5.6% to 6.0%	50% or Reject	50%
6.1% and over	50% or Reject	50% or Reject

PROPOSAL GUARANTY (1-37-1217)

As an evidence of good faith in submitting a bid for this work, the bidder shall indicate the type of bid bond applied to this project in accordance with Subsection 102.14 of the Standard Specifications.

500INFJAN18

INDEX

ACCEPTANCE TESTING OF SOILS BY USE OF THE LIGHT WEIGHT DEFLECTOMETER (LWD) SCOPE 35

ASPHALTIC CONCRETE PLACEMENT 44

BITUMINOUS LIQUID COMPOUNDS FOR CURING CONCRETE 61

COLD MILLING CLASS 3 43

CONCRETE PAVEMENT REPAIR 47

CONSTRUCTION DETAILS 20

CONSTRUCTION METHODS 22

CONSTRUCTION STORMWATER MANAGEMENT CONTROL 21

COVERCROP SEEDING 49

ENVIRONMENTAL COMMITMENT 16

ENVIRONMENTAL COMMITMENT DOCUMENT 24

ENVIRONMENTAL COMMITMENT ENFORCEMENT 27

GENERAL CONDITIONS 6

HAZARDOUS MATERIALS MANAGEMENT 32

HYDRATED LIME FOR ASPHALT MIXTURES 49

HYDRATED LIME SLURRY FOR ASPHALT MIXTURES 52

INCENTIVE PAYMENT FOR THE USE OF RECYCLED ASPHALTIC PAVEMENT (RAP) FOR ASPHALTIC MIXTURES 60

LIABILITY INSURANCE 19

LIMITATION OF OPERATIONS 22

NOTICE TO BIDDERS 14

PERFORMANCE GRADED BINDER 49

PERMANENT PAVEMENT MARKING 43

POLYESTER GEOGRID-FABRIC COMPOSITE 44

PROPOSAL GUARANTY 62

PROPOSAL GUARANTY BID BOND (BID BOND) 19

REQUIRED SUBCONTRACTOR/SUPPLIER QUOTATIONS LIST 18

SEEDING 48

SPECIAL PROSECUTION AND PROGRESS

(Federal Immigration Verification System) 19

(Milling/Asphaltic Concrete Placement) 14

(Polyester Geogrid-Fabric Composite Placement Location) 14

STATUS OF ENVIRONMENTAL COMMITMENTS 15

STATUS OF RIGHT OF WAY 13

STATUS OF UTILITIES 13

STORM WATER DISCHARGES 17

STORM WATER POLLUTION PREVENTION PLAN (SWPPP).....25
SUPERPAVE ASPHALTIC CONCRETE.....62

TABULATION OF CORES
(FOR INFORMATION ONLY)47
TEMPORARY WATER POLLUTION CONTROL20
TRAINING SPECIAL PROVISIONS6
 AMENDMENT TO CONSTRUCTION TRAINING REPORT REQUIREMENTS.....13

WET REFLECTIVE THERMOPLASTIC PAVEMENT MARKING, GROOVED38
WORK ZONE TRAFFIC CONTROL SIGNS38
WORKER VISIBILITY18

